

[illegible]

 13 mm GYPSUM BOARD LAMINATED TO SUBSTRATE	 13 mm GYPSUM BOARD ON METAL STUD FRAMING AT 400 O.C.	 26 mm 2 LAYERS 13 mm GYPSUM BOARD 41 mm METAL STUD FRAMING AT 400 O.C. SPACED MIN. 15mm FROM SUBSTRATE, WITH SOUND ATTENUATION BATTS	 13 mm GYPSUM BOARD 92 mm METAL STUD FRAMING AT 400 O.C. ON SPACED MIN. 15mm FROM SUBSTRATE 92 mm	 13 mm GYPSUM BOARD ON METAL STUD FRAMING AT 400 O.C.	
 13 mm GYPSUM BOARD 22 mm FURRING CHANNELS AT 400 O.C.	 13 mm GYPSUM BOARD 41 mm METAL STUD FRAMING AT 400 O.C. (50 mm) 70 MIN.	 26 mm 2 LAYERS 13 mm GYPSUM BOARD 92 mm METAL STUD FRAMING AT 400 O.C. WITH SOUND ATTENUATION BATTS	 19 mm WOOD VENEER PANEL ON CONCEALED STUD SYSTEM (REFER TO INTERIOR DESIGN DRAWINGS)	 13 mm GYPSUM BOARD ON METAL STUD FRAMING AT 400 O.C. WITH SOUND ATTENUATION BATTS 41 mm (75 mm) AIR SPACE (MIN.) 18 mm	

FL1 SLAB ON GRADE - LEVELS P1 AND P2 100 VARIES 100 mm SEALER (REFER TO ROOM FINISH SCHEDULE AND SPECIFICATION) CAST-IN-PLACE CONCRETE SLAB (REFER TO STRUCTURAL). SLOPE MIN. 2% AT PARKING AREAS 200mm MIN. COMPACTED CLEAR 19mm CRUSHED LIMESTONE SUBDRAINAGE (REFER TO MECHANICAL)	FL2 SUSPENDED CONCRETE SLAB - PARKING LEVELS VARIES 200 mm POLYURETHANE VEHICULAR TRAFFIC TOPPING ON 230mm MIN. CAST-IN-PLACE REINFORCED CONCRETE SLAB (REFER TO STRUCTURAL). SLOPE MIN. 2% AT PARKING AREAS	FL3 SUSPENDED CONCRETE SLAB VARIES 200mm MIN. CAST-IN-PLACE REINFORCED CONCRETE SLAB (REFER TO STRUCTURAL) 2 HOUR F.R.R.	FL4 HEAT TRACED ASPHALT TOPPING ON CONCRETE RAMP 90 mm 7 mm 3 mm VARIES HIGH STABILITY ASPHALTIC CONCRETE WEAR COURSE WITH HEATING CABLE SYSTEM (REFER TO SPECIFICATION) ASPHALT IMPREGNATED FIBREBOARD BOARD HOT RUBBERIZED ASPHALT WATERPROOFING MEMBRANE 230 mm MIN. CAST-IN-PLACE REINFORCED CONCRETE SLAB (REFER TO STRUCTURAL) 2 HOUR F.R.R.	FL5 RADIANT HEATING ON CONCRETE SLAB 64mm 75mm VARIES FINISHED FLOORING ON FLOORING SUBSTRATE (REFER TO INTERIOR DESIGN DRAWINGS) 2 SHEETS 3/2" PLYWOOD ON 1" RUBBER PAD SLAB DEPRESSION - DRY PACK - WITH SAND CEMENT WITH WELDED WIRE MESH AND RADIANT HEATING HYDRONIC PIPING 200 mm MIN. REINFORCED SUSPENDED CONCRETE SLAB OR SLAB ON GRADE CAST-IN-PLACE CONCRETE SLAB (REFER TO STRUCTURAL) WITH 100 mm RIGID INSULATION 200 mm MIN. COMPACTED 19mm CLEAR CRUSHED LIMESTONE	FL5A RADIANT HEATING ON CONCRETE SLAB 50mm VARIES FINISHED FLOORING ON FLOORING SUBSTRATE (REFER TO INTERIOR DESIGN DRAWINGS) SLAB DEPRESSION - DRY PACK - WITH SAND CEMENT WITH WELDED WIRE MESH AND RADIANT HEATING HYDRONIC PIPING 200 mm MIN. REINFORCED SUSPENDED CONCRETE SLAB OR SLAB ON GRADE CAST-IN-PLACE CONCRETE SLAB (REFER TO STRUCTURAL) WITH 100 mm RIGID INSULATION 200 mm MIN. COMPACTED 19mm CLEAR CRUSHED LIMESTONE	FL6 FLOOR GRILL IN 90 RECESS ON CONCRETE SLAB 50 mm VARIES 50 mm FRAME 50 mm VARIES STAINLESS STEEL BAR GRILL IN STAINLESS STEEL ANGLE (REFER TO SPECIFICATION) ON LEVELLING SCREED ON 200 mm MIN. REINFORCED SUSPENDED CONCRETE SLAB OR 100 mm MIN. CONCRETE SLAB ON GRADE ON 200 mm MIN. COMPACTED 19 mm CLEAR CRUSHED LIMESTONE	FL7 HOT TUB PODIUM STONE SLAB FINISH ON CONCRETE SLAB 50 mm 25 mm VARIES STONE SLAB (SEE LANDSCAPE DRAWINGS) MORTAR SETTING BED 200 mm MIN. REINFORCED CONCRETE STRUCTURE (SEE STRUCTURAL)
FL8 CERAMIC TILE FINISH ON CONCRETE SLAB 64 VARIES CERAMIC TILE (THICKNESS VARIES, REFER TO INTERIOR DRAWINGS) ON MORTAR SETTING BED (REFER TO SPECIFICATION) 200 mm MIN. REINFORCED CONCRETE SLAB (REFER TO STRUCTURAL)	FL9 ENGINEERED WOOD FINISH ON CONCRETE SLAB 64 VARIES FINISHED FLOORING ON FLOORING SUBSTRATE (REFER TO INTERIOR DESIGN DRAWINGS) 2 SHEETS 3/2" PLYWOOD ON 1" RUBBER PAD 200 mm MIN. REINFORCED CONCRETE SLAB (REFER TO STRUCTURAL)	FL10 CARPET IN SUITES 6 mm 6 mm VARIES CARPET (REFER TO INTERIOR DESIGN) ON UNDERLAYMENT (REFER TO SPECIFICATION) ON SUBSTRUCTURE	FL11 HARD SURFACED FLOORING IN SUITES VARIES 200 mm MIN. REINFORCED CONCRETE SLAB	FL12 CARPET IN THEATRE 6 mm 6 mm VARIES CARPET (REFER TO INTERIOR DESIGN) ON UNDERLAYMENT (REFER TO SPECIFICATION) ON SUBSTRUCTURE	FL13 FLOATING CONCRETE SLAB 100 mm 19 mm 50 mm VARIES CONCRETE SLAB (REFER TO STRUCTURAL) EXT. GRADE PLYWOOD RESILIENT ISOLATION PADS ("PLUCKS") WITH 38mm ACOUSTIC BLANKET REINFORCED CONCRETE SLAB (REFER TO STRUCTURAL)	FL15 FLOATING CONCRETE SLAB 200 mm 5 mm VARIES CONCRETE SLAB WITH SEPARATION LAYER ON REINFORCED CONCRETE SLAB (REFER TO STRUCTURAL)	

C1	SUSPENDED GYPSUM BOARD CEILING TYPICAL SUITES	C2	SUSPENDED ACOUSTIC TILE CEILING	C3	SUSPENDED GYPSUM BOARD ACOUSTIC CEILING	C3A	SUSPENDED GYPSUM BOARD ACOUSTIC CEILING AT GROUND LOBBY	C4	2 HOUR FRR GYPSUM SHAFTWALL BULKHEAD	C5	GYPSUM BOARD BULKHEAD	C5A	GYPSUM BOARD BULKHEAD
	300 16 mm GYPSUM BOARD 22 mm METAL FURRING CHANNELS 41/64 mm METAL STUD FRAMING 90 mm SOUND ATTENUATION BATT INSULATION LOOSE LAID OVER ENTIRE SUSPENSION SYSTEM REINFORCED SUSPENDED CONCRETE SLAB WITH ACOUSTIC UNDERLAYMENT AT HARD SURFACED FLOORS ABOVE -SEE SUITES FINISH SCHEDULE	300 610mm X 610mm ACOUSTIC TILES IN T BAR FRAMING SYSTEM (REFER TO SPECIFICATION) 90mm SOUND ATTENUATION BATT INSULATION LOOSE LAID OVER ENTIRE SUSPENSION SYSTEM REINFORCED SUSPENDED CONCRETE SLAB WITH ACOUSTIC UNDERLAYMENT AT HARD SURFACED FLOORS ABOVE -SEE SUITES FINISH SCHEDULE	300 32 mm 2 LAYERS 16mm GYPSUM BOARD 22 mm METAL FURRING CHANNELS 41/64 mm METAL STUD FRAMING 140 mm SOUND ATTENUATION BATT INSULATION LOOSE LAID OVER ENTIRE SUSPENSION SYSTEM REINFORCED SUSPENDED CONCRETE SLAB WITH ACOUSTIC UNDERLAYMENT AT HARD SURFACED FLOORS ABOVE -SEE SUITES FINISH SCHEDULE	600 32 mm 2 LAYERS 16mm GYPSUM BOARD 22 mm METAL FURRING CHANNELS 22 mm METAL STUD FRAMING 152 mm SOUND ATTENUATION BATT INSULATION LOOSE LAID OVER ENTIRE SUSPENSION SYSTEM REINFORCED SUSPENDED CONCRETE SLAB WITH ACOUSTIC UNDERLAYMENT AT HARD SURFACED FLOORS ABOVE -SEE SUITES FINISH SCHEDULE	103 HORIZONTAL COMPONENT: 39 mm 2 LAYERS 13 FIRE CODE GYPSUM BOARD ON C-H STUDS AT 610 O.C. 64 mm GYPSUM LINER BOARD 25 mm GYPSUM LINER BOARD VERTICAL COMPONENT: 26 mm 2 LAYERS 13 FIRE CODE GYPSUM BOARD ON C-H STUDS AT 610 O.C. 64 mm GYPSUM LINER BOARD 25 mm GYPSUM LINER BOARD O.B.M.E.C. AUTHORIZATION 88-1-118	13 13 mm GYPSUM BOARD 41 mm METAL STUD FRAMING AT 400 O.C. SERVICES SPACE (MIN.) 90 mm SOUND ATTENUATION BATTS AT CEILING AREAS WITH DRAINAGE PIPES	39 39 mm 3 LAYERS 13mm GYPSUM BOARD METAL STUD FRAMING						
C6	SUSPENDED WOOD VENEER CEILING / BULKHEAD	C7	SUSPENDED GYPSUM BOARD CEILING WITH HEATED PLENUM	C8	SUSPENDED BACKPAINTED GLASS CEILING	C9	ACOUSTIC CEILING	C10	150mm FACED INSULATION CEILING	C11	100 mm FACED INSULATION CEILING	C12	ACOUSTIC CEILING 100mm DEEP
	19 19 mm WOOD VENEER BOTH SIDES PARTICLE CORE PLYWOOD WITH CONCEALED FASTENING SYSTEM (SEE INTERIOR DRAWINGS) 92 mm METAL STUD FRAMING AT 400 O.C. WITH ACOUSTIC ISOLATORS ON HANGARS 140 mm SOUND ATTENUATION BATT INSULATION LOOSE LAID OVER ENTIRE SUSPENSION SYSTEM REINFORCED CONCRETE SLAB (REFER TO STRUCTURAL DRAWINGS)	26 26 mm 2 LAYERS 13mm GYPSUM BOARD ON VARIABLES SUSPENDED METAL STUD FRAMING SYSTEM 150mm THERMAL INSULATION BATTS LOOSE LAID OVER ENTIRE SUSPENSION SYSTEM 200 mm HEATED AIR PLENUM (SEE MECHANICAL DRAWINGS) VARIABLES REINFORCED SUSPENDED CONCRETE SLAB	6 6 mm MIN. TEMPERED BACKPAINTED GLASS PANELS IN VARIABLES CONCEALED METAL CHANNEL FRAMING SYSTEM 92 mm METAL STUD FRAMING AT 400 O.C. VARIABLES SOUND ATTENUATION AS PER ADJACENT CEILING ASSEMBLIES REINFORCED CONCRETE SLAB (REFER TO STRUCTURAL)	32 32 mm 2 LAYERS 16 mm GYPSUM BOARD 26 mm METAL FURRING CHANNELS 22 mm METAL STUD FRAMING 140 mm SOUND ATTENUATION BATT INSULATION LOOSE LAID OVER ENTIRE SUSPENSION SYSTEM REINFORCED SUSPENDED CONCRETE SLAB	150 150 mm WHITE FACED 150 mm SEMI-RIGID INSULATION ASTM C612 TYPE 1A PINNED TO UNDERSIDE OF CONCRETE SLAB R 27	100 100 mm WHITE FACED 100 mm SEMI-RIGID INSULATION ASTM C612 TYPE 1A PINNED TO UNDERSIDE OF CONCRETE SLAB R 18	16 16 mm GYPSUM BOARD 22 mm METAL FURRING CHANNELS 62 mm METAL Z CHAIRS / METAL FRAMING 50 mm SOUND ATTENUATION BATT AT CEILING AREAS WITH DRAINAGE PIPES						