

ASI No. 29

<i>to</i>	DELTERA 4800 Dufferin Street Toronto Ontario M3H 5S9	<i>project:</i>	SQ ALEXANDRA PARK BLOCK 11 CONDOMINIUM
<i>attention</i>	FRED FOO ffoo@deltera.com	<i>project no.:</i>	12-115
		<i>date:</i>	February 22, 2016

Site Instructions are issued for the purposes of recording any clarification or interpretation of the contract documents or giving direction on problems resulting from field conditions. These instructions are subject to the provisions of the contract documents and unless stated herein and specifically authorized by the Client, will not affect the contract. Should the Contractor require a change in the contract price or project schedule, he shall submit to the Architect an itemized proposal. If the Client accepts the proposal, a Change Order will supersede this Site Instruction. When used as a Field Order, the Instruction should clearly state the accounting basis on which the work is to proceed and whether there is a change to the proposed schedule.

1. TITLE

(1 page)

Suites 228, 328, 428, 528, 628, 728, 828, 928, 1028, 1128

2. REFERENCES (Enclosed)

A206, A208, A210, A212, A214, A216, A218, A220, A221, A222

3. DESCRIPTION OF WORKSuites 228, 328, 428, 528, 628, 728, 828, 928, 1028, 1128:

Delete sliding glass doors and closet from interior bedroom.

4. REASONS

Design coordination

END OF SITE INSTRUCTION ASI No. 29

Tanya Cazzin OAA

cc:

David Dawe
Deltera

ddawe@deltera.com

Michael Monopoli
Tridel

mmonopoli@tridel.com

Victor Guarini
Tridel

vguarini@tridel.com