



GENERAL AREA CIRCUITING - TABLE #1			
HITTING FIXTURE LOCATION	CCT #	RECECTABLE LOCATION	CCT.
TO F1 - EXIT SIGNS	EX-XX	LOBBY (F4 TO F1)	EX-XX
TO 10/F - EXIT SIGNS	EX-XX	STAIR "A" (5/F2/F2)	EX-XX
TO ROOF - EXIT SIGNS	EX-XX	STAIR "B" (M4302124210)B,5/F	EX-XX
LOBBY (F4 TO F1)	EX-XX	STAIR "B" (12/36,3/F4/FLOORS	EX-XX
STAIR "A" (F4 TO 5/F)	EX-XX	STAIR "C" (M4302124212) FLOORS	EX-XX
	EX-XX	STAIR "C" (18/5) 5/F FLOORS	EX-XX
	EX-XX	STAIR "D" (F4/F4) FLOORS	EX-XX
	EX-XX	STAIR "E" (F1) FLOOR	EX-XX
	EX-XX	CORRIDOR	EX-XX

- 1) FOR CIRCUITING, REFER TO TABLE #1.
- 2) PROVIDE ALARM SPEAKER, SMOKE DETECTOR AND RECEPTACLE AT EVERY THIRD FLOOR STAIR WELL STARTING FROM TOP FLOOR, AS PER TO DUG. E-32 FOR FIRE ALARM RISER DIAGRAM.
- 3) REFER TO SUPERVISED VALVE AND FLOW SWITCH SCHEDULE ON DUG. E-XX FOR DETAILS ON TYPICAL FLOORS.
- 4) PROVIDE TELECOMMUNICATION BACKBOARD C/W 115V, 1Ø, 15A RECEPTACLE AS PER COMMUNICATION RISER DIAGRAM ON DUG. E-31.
- 5) CONTRACTOR SHALL REFER TO ELECTRICAL SINGLE LINE DIAGRAM ON DUG. E-30 AND SDF RISER ON DUG. E-31 FOR SDF LOCATIONS AND DISTRIBUTION.
- 6) PROVIDE CONDUIT AS PER RISER DETAIL #3 ON DUG. E-35 FOR BISORTER/TRISORTER CONTROL SYSTEM.
- 7) ALL SUITE DOOR CONTACTS WILL COMPLETE WITH INTRUSION ALARM SYSTEM THAT CONTACT TO THE CONCIERGE STATION.
- 8) DESIGNATED "LAUNDRY RECEPTACLE" AS DEFINED BY ESA CODE 26-26-0 (e) 26-26(2)(b) (LAUNDRY BULLETIN 26-26-0) (WITHIN 2m RADIUS OF LAUNDRY CLOSET). RECEPTACLE SHALL BE CONNECTED TO A DEDICATED CIRCUIT. SEE DETAIL #4 ON DUG. E-35.
- 9) SWITCHES, RECEPTABLES, ETC., TO BE INSTALLED AS TO NOT INTERFERE WITH THE OPENING AND OPERATION OF SLIDING DOOR.

TELECOMMUNICATION	
	TV/CABLE OUTLET
	TELEPHONE OUTLET
	TELEPHONE/TV CABLE (MULTI-PORT OUTLET)
	DATA OUTLET
	DATA/TELEPHONE OUTLET
	IN SUITE TELECOMM. BOX C/W RECEPTACLE
	WIFI LOCATION
	MUSIC SPEAKER / VOLUME CONTROL
	AUDIO RECEPTACLE

LIFE SAFETY	
	FIRE ALARM SMOKE DETECTOR
	SMOKE ALARM
	EXHAUST DUCT TYPE SMOKE DETECTOR
	FIXED TEMP. 68 °F DEGREE HEAT DETECTOR
	MOISTURE PROOF HEAT DETECTOR
	CO ALARM
	COMBINATION SMOKE & CO ALARM
	CO SENSOR / NO SENSOR
	FIRE ALARM MANUAL PULL STATION
	FIREFIGHTER'S HANDSET
	FIRE ALARM STROBE/ALARM WALL MTD.
	FIRE ALARM MINI-HORN WALL MTD.
	FIRE ALARM STROBE/SMOKE CEILING MTD.
	FIRE ALARM SPEAKER CEILING MTD.
	FIRE ALARM ANNUNCIATOR PANEL
	FIRE ALARM CONTROL PANEL

THANK YOU ALL PRINTED DATED HERE/BOX TO FINAL DATE ABOVE			
INVENTORY	1	MAILED FOR ---	53
DATE	NO.	DESCRIPTION	BY
REVISIONS			
CONTRACTOR THAT CHECK AND VERIFY ALL DIMENSIONS AND CONDITIONS PROCEEDING WITH THE WORK. THIS ORIGINALLY IS THE PROPERTY OF THE ENGINEERS AND MUST BE RETURNED UPON COMPLETION OF THE WORK.			
DRAWINGS ARE NOT TO BE SCALE FD.			

NOVA
TREND
ENGINEERING
CONSULTING LTD.

175 West Beaver Creek Road, Unit 31
Richmond Hill, Ontario L4B 3H1
Tel: 905-882-5446
Fax: 905-882-5447
Email: cad@mocatrendeng.com

PROJECT: 4/F NORTH FLOOR PLAN
ELECTRICAL LAYOUT

PROJECT TITLE:
ALEXANDRA PARK

XXXX
TORONTO ONTARIO

DRAWN BY: S.O.	CHECKED BY: G.T.	SCALE: 1:50
DATE: FEB, 13	PROJECT NUMBER: 1313	DRAWING NUMBER: E-13 OF

