



GENERAL AREA CIRCUITING - TABLE #1			
LIGHTING FIXTURE LOCATION	CCT.	RECEPTACLE LOCATION	CCT.
G-4 TO PL - EXIT SIGNS	EX-XX	LOBBY (P-4 TO PL)	EX-XX
G-6 TO 10/F - EXIT SIGNS	EX-XX	STAIR "A" (B-2,F-2P)	EX-XX
1/F TO ROOF - EXIT SIGNS	EX-XX	STAIR "B" (M-2,30,21,24,21)B & FLOORS	EX-XX
LOBBY (P-4 TO PL)	EX-XX	STAIR "B" (12,2,3,F-11)B & FLOORS	EX-XX
STAIR "A" (P-4 TO G/F)	EX-XX	STAIR "C" (M-4,30,21,24,21) FLOORS	EX-XX
CORRIDOR	EX-XX	STAIR "C" (12,2,3,F-11)B & FLOORS	EX-XX
	EX-XX	STAIR "D" (P-1,F-4) FLOORS	EX-XX
	EX-XX	STAIR "E" (F-1) FLOORS	EX-XX
	EX-XX	CORRIDOR	EX-XX

- KEY NOTES - RESIDENTIAL:**
- ① FOR CIRCUITING, REFER TO TABLE #1.
 - ② PROVIDE ALARM SPEAKER, SMOKE DETECTOR AND RECEPTACLE AT EVERY THIRD FLOOR STAIR WELL STARTING FROM TOP FLOOR, AS PER TO DUGS E-35 FOR FIRE ALARM RISER DIAGRAM.
 - ③ REFER TO SUPERVISED VALVE AND FLOW SWITCH SCHEDULE ON DUGS. E-XX FOR DETAILS ON TYPICAL FLOORS.
 - ④ PROVIDE TELECOMMUNICATION BACKBOARD C/W 15V, 15A RECEPTACLE AS PER COMMUNICATION RISER DIAGRAM ON DUGS E-31.
 - ⑤ CONTRACTOR SHALL REFER TO ELECTRICAL SINGLE LINE DIAGRAM ON DUGS E-30 AND SDP RISER ON DUGS E-31 FOR SDP LOCATIONS AND DISTRIBUTION.
 - ⑥ PROVIDE CONDUIT AS PER RISER DETAIL #9 ON DUGS E-35 FOR BISCORNER/TRISCORNER CONTROL SYSTEM.
 - ⑦ ALL SUITE DOOR CONTACTS WILL COMPLETE WITH INTRUSION ALARM SYSTEM THAT CONTACT TO THE CONCIERGE STATION.
 - ⑧ DESIGNATED "LAUNDRY RECEPTACLE" AS DEFINED BY ESA CODE 26-110(e)(ii), 26-120(b) and ESA BULLETIN 26-26-0 (WITHIN 3M RADIUS OF LAUNDRY CLOSET). RECEPTACLE SHALL BE CONNECTED TO A DEDICATED CIRCUIT. SEE DETAIL #4 ON DUGS E-35.
 - ⑨ SWITCHES, RECEPTACLES, ETC., TO BE INSTALLED AS TO NOT INTERFERE WITH THE OPENING AND OPERATION OF SLIDING DOOR.
 - ⑩ CONTRACTOR SHALL REFER TO ELECTRICAL CONTRACTOR TO SUPPLY AND INSTALL CONDUIT, AND JUNCTION BOX FOR REMOTE THERMOSTAT.
 - ⑪ ELECTRICAL CONTRACTOR TO SUPPLY AND WIRE THERMOSTATS, MOUNT

TELECOMMUNICATION	
▽	TV/CABLE OUTLET
▽	TELEPHONE OUTLET
▽	TELEPHONE CABLE (MULTI-PORT OUTLET)
▽	DATA/TELEPHONE CABLE
▽	DATA/TELEPHONE BOX C/G RECEPTACLE
▽	WIFI LOCATION
160 / 161	MUSIC SPEAKER / VOLUME CONTROL
SECURITY	
162 / 163	INTERCOM / INTERPHONE
164	INTERCOM WITH CAMERA
165 / 168	PANIC BUTTON / PANIC INTERCOM STATION
166	CARD READER
167A / 168	ACCESS RELEASE CARD ACCESS/RADIO RECEIVER
168	ELECTRIC STRIKE RECEIVER
169	MAGLOCK
169 / 170	DOOR CONTACT / WINDOW CONTACT
170	PERIMETER DOOR-DOOR OPERATOR
171	MOTION DETECTOR
172	FLUSH BUTTON
□	SECURITY CAMERA

LIFE SAFETY	
	FIRE ALARM SMOKE DETECTOR
	SMOKE ALARM
	FIRE ALARM DUCT TYPE SMOKE DETECTOR
	FIXED TEMP. 68 °C DEGREE HEAT DETECTOR
	MOUSSE PROOF HEAT DETECTOR
	CO ALARM
	COMBINATION SMOKE & CO ALARM
	NO SENSOR / NO SENSOR
	FIRE ALARM MANUAL PULL STATION
	FIREFIGHTER'S HANDSET
	FIRE ALARM STROBES/HORN, WALL, TWT
	FIRE ALARM TMD-HORN, WALL, TWT
	FIRE ALARM SPEAKER-STROBE, CEILING, TWT
	FIRE ALARM SPEAKER, CEILING, TWT
	FIRE ALARM ANNUNCIATOR PANEL
	FIRE ALARM CONTROL PANEL

[illegible]

05/08/14	1	ISSUED FOR PERMIT	SL
DATE	NO.	DESCRIPTION	BY
MARK VOID ALL PRINTS DATED PREVIOUS TO FINAL DATE ABOVE			

REVISIONS
 CONTRACTOR MUST CHECK AND VERIFY ALL DIMENSIONS AND CONDITIONS
 ON THE JOB AND REPORT DISCREPANCIES TO THE ENGINEERS BEFORE
 PROCEEDING WITH THE WORK. THIS DRAWING IS THE PROPERTY OF THE
 ENGINEERS AND MUST BE RETURNED UPON COMPLETION OF THE WORK.
 DRAWINGS ARE NOT TO BE SCALED



175 West Beaver Creek Road, Unit 31
Richmond Hill, Ontario L4B 3M1
Tel: 905 882-5445
Fax: 905 882-5447
Email: cad@novatrendeng.com

DRAWING TITLE:
2/F SOUTH FLOOR PLAN
ELECTRICAL LAYOUT

PROJECT TITLE:
ALEXANDRA PARK

XXX
TORONTO

ONTARIO

DRAWN BY: S.O.	CHECKED BY: S.T.	SCALE: 1:50
DATE:	PROJECT NUMBER:	DRAWING NUMBER:

FEB, 13	1313	E-8 OF
---------	------	--------