

POST TENDER ADDENDUM NO. E-1  
ELECTRICAL WORK  
FOR  
ALEXANDRA PARK

DELTERA

NOVATREND ENGINEERING GROUP LTD.

---

Date: January 08, 2015

1. Reference drawing E-1 Layout (Issued)
  - a. Revised drawing list.
  - b. Revised notes. (Acoustic changes)
2. Reference drawings E-2 Layout (Issued)
  - a. Removed housekeeping pad for T1,2,3,4,TE1,2. (Acoustic changes)
  - b. Revised general note. (clarification)
  - c. Added electrical connection and circuits for FHC units.
3. Reference drawings E-3 Layout (Issued)
  - a. Revised general note. (clarification)
  - b. Added electrical connection and circuits for FHC units.
  - c. Added card reader, electrical strike and door contact. (Arch.)
  - d. Added EF-12 & MD as per Mechanical changes.
4. Reference drawings E-6 Layout (Issued)
  - a. Added note. (Arch.)
  - b. Revised lighting layout. (Arch.)
5. Reference drawings E-22 Layout (Issued)
  - a. Added heat tracing connection for FHC, electrical connection for 3kw FFH heater.
  - b. Added light fixture type. (clarification)
6. Reference drawings E-33 Layout (Issued)
  - a. Revised trouble panel schedule.
7. Reference drawings E-34 Layout (Issued)
  - a. Revised lighting schedule. (Arch.)
  - b. Revised panel schedule. (clarification)