

S.I. #E-5/Lighting Addendum # 1
ELECTRICAL WORK
FOR
ALEXANDRA PARK

DELTERA

NOVATREND ENGINEERING GROUP LTD.

Date: June 17, 2015

This Site Instruction is issued to incorporate landscape lighting changes, security changes, Gym equipment layout changes, I.D drawing changes, architectural background changes, suite layout changes and provident comments as requested by Tridel

1. Reference drawings E-1, Site Plan (Issued)
 - a. Revised Landscape Lighting as per changes requested by Tridel.
 - b. Relocated one camera near suite 101 as per security mark up.
 - c. Added one camera near suite 121 as per security mark up.
 - d. Added DC, ML, PB, and Fire alarm pull station at walk way door as per security mark up.
2. Reference drawings E-4, GF Power (Issued)
 - a. Deleted 2 cameras at Private Terrace near Grid 10-13/A-C, and added 1 camera in the Residential Bike Storage #145 as per security mark up.
 - b. Added a new smoke detector and a new receptacle in the new egress corridor as per architectural background change.
 - c. Relocated the electrical devices in the Parcel Room to accommodate the new background.
 - d. Revised the power outlets and circuits of fitness equipment as per latest gym equipment layout.
 - e. Revised suite layout as per Blackline.
3. Reference drawings E-5, GF Power (Issued)
 - a. Added 2 cameras in the Loading Area and Stair H as per security mark up.
 - b. Relocated IC outside of Loading Area as per security mark up.
 - c. Revised suite layout as per Blackline.
4. Reference drawings E-6, E-7, GF LTG (Issued)
 - a. Revised the lighting layout as shown as per ID drawing changes.
 - b. Revised suite layout as per Blackline.
 - c. Added two exit signs and an Occupancy Sensor at the new Egress Corridor as per architectural background change.
5. Reference drawings E-8 to E-12, E-14-E17, E-19, E-22 to E-28 (Issued)

- a. Revised suite layout as per Blackline.
- 6. Reference drawing E-30, Single Line Diagram(Issued)
 - a. Revised the fuse trip setting from 25A to 15A as shown as per Provident comment.
- 7. Reference drawing E-34, Electrical Panel & Lighting Schedule(Issued)
 - a. Revised Ground Floor Landscape Lighting Schedule as shown.
 - b. Revised the panel "LP-B1" as per latest gym equipment layout.
 - c. Revised the breaker size for EF-22 as per Shop drawing.
 - d. Revised WS fixture at Cooling Tower as shown.
 - e. Revised I.D lighting schedule as per I.D Changes.
- 8. Reference drawing E-35, Electrical Detail (Issued)
 - a. Revised Detail #18 as per provident comment.