



- 1) NO BX CABLE TO BE USED.
- 2) ACTUAL LOCATION OF METERING CENTRE (MC) TO BE DETERMINED BY ELECTRICIAN. LOWEST POSSIBLE FLOOR 4 IN A CLOSET WITHOUT A SUITE DISTRIBUTION PANEL.
- 3) METERING CENTRE (MC) REQUIRES 120V POWER & JUNCTION BOX.
- 4) 1ST JUNCTION BOX FOR SUITE DISTRIBUTION PANEL (FROM THE BOTTOM) REQUIRES 120V POWER.
- 5) HOME RUN FLOOR TO BE DETERMINED BY ELECTRICIAN.
- 6) ALL CABLE USED TO MEET OBC 3.15.10.