



- ① 250° COMBUSTION AIR INTAKE AND 250° EXHAUST FROM BOILERS B-1, 2 BELOW C/W TERMINATION FITTING, AS PER MANUFACTURER'S INSTALLATION MANUAL AND TSSA REQUIREMENTS.
- ② 300° COMBUSTION AIR INTAKE AND 2225° EXHAUST FROM BOILER B-3 BELOW C/W TERMINATION FITTING, AS PER MANUFACTURER'S INSTALLATION MANUAL AND TSSA REQUIREMENTS.
- ③ REFRIGERANT PIPES TO/FROM RESPECTIVE CONDENSER UNIT BELOW (HCU-37). REFER TO MANUFACTURER'S RECOMMENDATIONS FOR PIPE SIZES.
- ④ EF-27 TO BE FLUSHED WITH INTERIOR WALL - FAN MOTOR TO BE T.E. (TOTALLY ENCLOSE) AND NEMA-3R DISCONNECT WHICH IS "RAIN TIGHT".
- ⑤ 800x400 WEATHERPROOF INTAKE LOUVER C/W MOTORIZED DAMPER AND 800x400 SUPPLY GRILLE FLUSH WITH THE INTERIOR.

DRAWN BY: G.S.	CHECKED BY: E.P.	SCALE: 1:50
DATE: FEB, 13	PROJECT NUMBER: 1313	DRAWING NUMBER: M-34 OF 43