

- 1) THIS CONTRACTOR TO INSTALL FIRE DAMPER FOR DUCTWORK PENETRATING FIRE RATED WALLS, FLOOR SLAB, ETC.
- 2) FRESH AIR SUPPLY DUCT TO BE c/w 25MM INTERNAL ACOUSTIC LINING FROM AHU TO AIR SHAFT AND UP THREE FLOORS.

