

2) FRESH AIR SUPPLY DUCT TO BE c/w 25MM
INTERNAL ACOUSTIC LINING FROM AHU TO AIR SHAFT AND UP
THREE FLOORS.

