Contractor Must Check And Verify All Dimensions On The Job.
Do Not Scale The Drawings.
All Drawings, Specifications And Related Documents Are The Copyright Of The Architect And Must Be Returned Upon Request.
Reproduction Of Drawings, Specifications And Related Documents In Part Or Whole Is Forbidden Without The Architect's Written Permission.
This Drawing Is Not To Be Used For Construction Until Signed By The Architect.

Date: October 2, 2015

ONTARIO ASSOCIATION OF ARCHITECTS
LICENCE
LE MICHAEL MCKINLEY
1001
SEAL MUST BE SIGNED TO BE VALID

Pricing Set

KIRKOR ARCHITECTS + PLANNERS
20 Martin Ross Avenue, Toronto, Ontario, M3J 2K8
TX (416) 630-0595, FAX (416) 665-1334, www.kirkorarchitects.com

No.	Revision	Date

PRICING SET
October 2, 2015

2.	Building Permit	June 12, 2015
1.	Waterfront Toronto Review	May 1, 2015
No.	Issued For	Date

AQUAVISTA
AT BAYSIDE TORONTO

Drawing Title
Wall Types
Exterior Wall Assemblies

Project
Hines TRIDEL
AQUAVISTA
Block 3 - R3 & R4
263 Queens Quay East
Toronto, ON

Scale
N.T.S.
Drawn by
M.N.
Checked by
C.A.
Project No.
13148
Date
October 2, 2015
Drawing No.
A8-03

E.I.F.S. Wall Construction — W5 / A8-03

SCALE N.T.S.

NOTE:
1. Maximum height guideline for block is 5040 (non-load bearing), 2800 (load bearing)
2. Refer to floor plans for interior partition type
3. Refer to Structural Engineering drawings for lateral support details and maximum height spans.
4. Provide mineral wool fire-stopping and smoke-seal caulk at gap between top of block and underside of structure above.
5. Continuity of fire-separation to be verified prior to covering/concealing in any way.

FIRE-RATING:
6. N.B.C. 2010 Table D-2.1.1 for Type S or N Concrete (O.B.C. 2012 SB-2 Table 2.1.1 for Type S or N Concrete)

1. EXTERIOR INSULATED FINISH SYSTEM

ALL E.I.F.S. WORK ON THIS PROJECT SHALL BE EXECUTED IN STRICT ACCORDANCE WITH E.I.M.A. PRACTICE BULLETIN 51.01 AND AN APPLICATOR WHO IS A MEMBER OF THE E.I.F.S. QUALITY ASSURANCE PROGRAM PROVIDE DUAL BARRIER WITH DRAINED CAVITY SYSTEM, ALL AS PER MANUFACTURER'S SPECS. ARRIVE ARCHITECTS & PLANNERS ACCEPTS NO RESPONSIBILITY WHATSOEVER FOR ANY WORK CARRIED OUT BY ANYONE CONTRACTED TO THIS PART OF BUT NOT APPROVED BY THE MANUFACTURER AND/OR WHO IS NOT A MEMBER OF E.I.F.S. ASSOC. DOES NOT FOLLOW E.I.M.A. PRACTICE BULLETIN 51.01.

EXTERIOR INSULATED FINISH SYSTEM
(REFER TO EXTERIOR MATERIAL SCHEDULE)
120 SEMI-RIGID INSULATION MIN. R.S.I 3.60
CONTINUOUS AIR RETARDER
140 CONCRETE BLOCK/ TOTAL SOLID (REFER TO P1) B2)

TYP.		F.R.R.	Nom.	R.S.I.	S.T.C.	NOM. THICKNESS
W5_B4	E.I.F.S. ON 140 CONCRETE BLOCK TOTAL SOLID	2.0 hr.	NOTE 4	3.60	-	365
W5_A2	E.I.F.S. ON STRUCTURAL CONCRETE	2.0 hr.	-	3.80	-	325

NOTE:
1. All form tie holes to be filled (Refer to specifications for detail)
2. Refer to floor plans for interior partition type
3. EXTERIOR INSULATED FINISH SYSTEM

ALL E.I.F.S. WORK ON THIS PROJECT SHALL BE EXECUTED IN STRICT ACCORDANCE WITH E.I.M.A. PRACTICE BULLETIN 51.01 AND AN APPLICATOR WHO IS A MEMBER OF THE E.I.F.S. QUALITY ASSURANCE PROGRAM PROVIDE DUAL BARRIER WITH DRAINED CAVITY SYSTEM, ALL AS PER MANUFACTURER'S SPECS. ARRIVE ARCHITECTS & PLANNERS ACCEPTS NO RESPONSIBILITY WHATSOEVER FOR ANY WORK CARRIED OUT BY ANYONE CONTRACTED TO THIS PART OF BUT NOT APPROVED BY THE MANUFACTURER AND/OR WHO IS NOT A MEMBER OF E.I.F.S. ASSOC. DOES NOT FOLLOW E.I.M.A. PRACTICE BULLETIN 51.01.

EXTERIOR INSULATED FINISH SYSTEM
(REFER TO EXTERIOR MATERIAL SCHEDULE)
120 SEM-RIGID INSULATION MIN. R.S.I 3.60
CONTINUOUS AIR RETARDER
STRUCTURAL CONCRETE (REFER TO STRUCTURAL DRAWINGS)

NOTE:
1. Refer to specifications for tint screen mesh and related items

STOREFRONT CURTAINWALL SYSTEM
(PRE-FINISHED METAL LOUVER)
GALVANIZED BIRD SCREEN MESH IN GALVANIZED FRAME

TYP.		F.R.R.	Nom.	R.S.I.	S.T.C.	NOM. THICKNESS
W4_C15	STOREFRONT METAL LOUVER CURTAINWALL SYSTEM	-	-	-	-	185

NOTE:
1. Refer to specifications for tint screen mesh and related items
2. For interior finish refer to room finish schedule

STOREFRONT CURTAINWALL SYSTEM
(PRE-FINISHED METAL LOUVER)
75 SEMI-RIGID INSULATION MIN. R.S.I. 2.28
GALVANIZED METAL BACK PAN FULLY SEALED TO PROVIDE AIR/VAPOUR BARRIER
VAPOUR BARRIER
13 GYPSUM BOARD FULLY SEALED TO PROVIDE AIR BARRIER

TYP.		F.R.R.	Nom.	R.S.I.	S.T.C.	NOM. THICKNESS
W4_C14	STOREFRONT METAL LOUVER CURTAINWALL SYSTEM	-	-	-	-	290

NOTE:
1. Max. stud height = 4875 ST25 (L.040)
2. For interior finish refer to room finish schedule
3. Provide fire-sealant around entire perimeter of wall at junction between stud track and floor/ceiling, both sides of wall.
4. Refer to ULC-W-402, System B for complete assembly requirements.

STOREFRONT CURTAINWALL SYSTEM
(PRE-FINISHED METAL SPANDREL PANEL)
75 SEMI-RIGID INSULATION MIN. R.S.I. 2.28
GALVANIZED METAL BACK PAN FULLY SEALED TO PROVIDE AIR/VAPOUR BARRIER
2 HOUR RATED SHAFTWALL (P11) (1) WHERE FIRE RATING IS NOTED ON FLOOR PLANS/ FULLY SEALED TO PROVIDE AIR BARRIER
75 MINERAL WOOL THERMAL INSULATION BLANKETS MIN. R.S.I 2.28
VAPOUR BARRIER

TYP.		F.R.R.	Nom.	R.S.I.	S.T.C.	NOM. THICKNESS
W4_C13	STOREFRONT METAL PANEL CURTAINWALL SYSTEM WITH FIRE RATED WALL	2.0 hr.	ULC-W-402 B	4.56	-	310

NOTE:
1. Max height = 4264 with CH stud 400CH-34 (L.040)
2. Refer to specifications for thickness and type of glass
3. For interior finish refer to room finish schedule
4. Provide fire-sealant around entire perimeter of wall at junction between stud track and floor/ceiling, both sides of wall.
5. Refer to ULC-W-402 or ULC-W-48A for complete assembly requirements.

STOREFRONT CURTAINWALL SYSTEM
(PRE-FINISHED METAL SPANDREL PANEL)
75 SEMI-RIGID INSULATION MIN. R.S.I. 2.28
GALVANIZED METAL BACK PAN FULLY SEALED TO PROVIDE AIR/VAPOUR BARRIER
2 HOUR RATED SHAFTWALL (P11) (1) WHERE FIRE RATING IS NOTED ON FLOOR PLANS/ FULLY SEALED TO PROVIDE AIR/VAPOUR BARRIER
75 MINERAL WOOL THERMAL INSULATION BLANKETS MIN. R.S.I 2.28
VAPOUR BARRIER

TYP.		F.R.R.	Nom.	R.S.I.	S.T.C.	NOM. THICKNESS
W4_C4	STOREFRONT METAL PANEL CURTAINWALL SYSTEM	-	-	4.69	-	290

NOTE:
1. Max. stud height = 4875 ST25 (L.040)
2. For interior finish refer to room finish schedule

STOREFRONT CURTAINWALL SYSTEM
(PRE-FINISHED METAL SPANDREL PANEL)
75 SEMI-RIGID INSULATION MIN. R.S.I. 2.28
GALVANIZED METAL BACK PAN FULLY SEALED TO PROVIDE AIR/VAPOUR BARRIER
90 METAL STUDS @ 400 "C
R5 THERMAL INSULATION BATTS MIN. R.S.I. 2.38
VAPOUR BARRIER
13 GYPSUM BOARD FULLY SEALED TO PROVIDE AIR BARRIER

TYP.		F.R.R.	Nom.	R.S.I.	S.T.C.	NOM. THICKNESS
W4_C3	STOREFRONT METAL PANEL CURTAINWALL SYSTEM	-	-	4.69	-	290

NOTE:
1. Max height = 4264 with CH stud 400CH-34 (L.040)
2. For interior finish refer to room finish schedule
3. Provide fire-sealant around entire perimeter of wall at junction between stud track and floor/ceiling, both sides of wall.
4. Refer to ULC-W-402, System B for complete assembly requirements.

STOREFRONT CURTAINWALL SYSTEM
(PRE-FINISHED METAL SPANDREL PANEL)
75 SEMI-RIGID INSULATION MIN. R.S.I. 2.28
GALVANIZED METAL BACK PAN FULLY SEALED TO PROVIDE AIR/VAPOUR BARRIER
2 HOUR RATED SHAFTWALL (P11) (1) WHERE FIRE RATING IS NOTED ON FLOOR PLANS/ FULLY SEALED TO PROVIDE AIR/VAPOUR BARRIER
75 MINERAL WOOL THERMAL INSULATION BLANKETS MIN. R.S.I 2.28
VAPOUR BARRIER

TYP.		F.R.R.	Nom.	R.S.I.	S.T.C.	NOM. THICKNESS
W4_C2	STOREFRONT METAL PANEL CURTAINWALL SYSTEM WITH FIRE RATED WALL	2.0 hr.	ULC-W-402 B	4.56	-	310

NOTE:
1. Max height = 4264 with CH stud 400CH-34 (L.040)
2. Refer to specifications for thickness and type of glass
3. For interior finish refer to room finish schedule
4. Provide fire-sealant around entire perimeter of wall at junction between stud track and floor/ceiling, both sides of wall.
5. Refer to ULC-W-402 or ULC-W-48A for complete assembly requirements.

STOREFRONT CURTAINWALL SYSTEM
(PRE-FINISHED METAL SPANDREL PANEL)
75 SEMI-RIGID INSULATION MIN. R.S.I. 2.28
GALVANIZED METAL BACK PAN FULLY SEALED TO PROVIDE AIR/VAPOUR BARRIER
2 HOUR RATED SHAFTWALL (P11) (1) WHERE FIRE RATING IS NOTED ON FLOOR PLANS/ FULLY SEALED TO PROVIDE AIR/VAPOUR BARRIER
75 MINERAL WOOL THERMAL INSULATION BLANKETS MIN. R.S.I 2.28
VAPOUR BARRIER

TYP.		F.R.R.	Nom.	R.S.I.	S.T.C.	NOM. THICKNESS
W4_C1	STOREFRONT METAL PANEL CURTAINWALL SYSTEM	-	-	4.69	-	290

NOTE:
1. Max height = 4264 with CH stud 400CH-34 (L.040)
2. Refer to specifications for thickness and type of glass
3. For interior finish refer to room finish schedule
4. Provide fire-sealant around entire perimeter of wall at junction between stud track and floor/ceiling, both sides of wall.
5. Refer to ULC-W-402 or ULC-W-48A for complete assembly requirements.

STOREFRONT SINGLE GLAZED CURTAINWALL SYSTEM
(SEALED SPANDREL GLASS SHADOW BOX UNIT)
75 SEMI-RIGID INSULATION MIN. R.S.I. 2.28
GALVANIZED METAL BACK PAN FULLY SEALED TO PROVIDE AIR/VAPOUR BARRIER
2 HOUR RATED SHAFTWALL (P11) (1) WHERE FIRE RATING IS NOTED ON FLOOR PLANS/ FULLY SEALED TO PROVIDE AIR/VAPOUR BARRIER
75 MINERAL WOOL THERMAL INSULATION BLANKETS MIN. R.S.I 2.28
VAPOUR BARRIER

TYP.		F.R.R.	NOTE	R.S.I.	S.T.C.	NOM. THICKNESS
W4_C9	STOREFRONT SPANDREL GLASS CURTAINWALL SYSTEM WITH FIRE RATED WALL	2.0 hr.	NOTE 5	4.56	-	310

Storefront Curtain Wall Construction — W4 / A8-03

SCALE N.T.S.

NOTE:
1. Maximum height guideline for block is 5040 (non-load bearing), 2800 (load bearing)
2. Refer to floor plans for interior partition type
3. Refer to Structural Engineering drawings for lateral support details and maximum height spans.
4. Provide mineral wool fire-stopping and smoke-seal caulk at gap between top of block and underside of structure above.
5. Continuity of fire-separation to be verified prior to covering/concealing in any way.

FIRE-RATING:
6. N.B.C. 2010 Table D-2.1.1 for Type S or N Concrete (O.B.C. 2012 SB-2 Table 2.1.1 for Type S or N Concrete)

STOREFRONT CURTAINWALL SYSTEM
(PRE-FINISHED METAL LOUVER)
100 SEMI-RIGID INSULATION MIN. R.S.I. 3.04
GALVANIZED METAL BACK PAN FULLY SEALED TO PROVIDE AIR/VAPOUR BARRIER
140 CONCRETE BLOCK

TYP.		F.R.R.	Nom.	R.S.I.	S.T.C.	NOM. THICKNESS
W4_C8	STOREFRONT SPANDREL GLASS CURTAINWALL SYSTEM	-	-	4.69	-	290

NOTE:
1. Maximum height guideline for block is 5040 (non-load bearing), 2800 (load bearing)
2. Refer to floor plans for interior partition type
3. Refer to Structural Engineering drawings for lateral support details and maximum height spans.
4. Provide mineral wool fire-stopping and smoke-seal caulk at gap between top of block and underside of structure above.
5. Continuity of fire-separation to be verified prior to covering/concealing in any way.

FIRE-RATING:
6a. N.B.C. 2010 Table D-2.1.1 for Type S or N Concrete (O.B.C. 2012 SB-2 Table 2.1.1 for Type S or N Concrete)
6b. ULC 12005 - Type LD-205 Concrete, ULC tested suppliers ONLY (2 hr. F.R.R).

STOREFRONT CURTAINWALL SYSTEM
(PRE-FINISHED METAL SPANDREL PANEL)
100 SEMI-RIGID INSULATION MIN. R.S.I. 3.04
GALVANIZED METAL BACK PAN FULLY SEALED TO PROVIDE AIR/VAPOUR BARRIER
190 CONCRETE BLOCK

TYP.		F.R.R.	Nom.	R.S.I.	S.T.C.	NOM. THICKNESS
W4_B9	STOREFRONT METAL PANEL CURTAINWALL SYSTEM ON 140 CONCRETE BLOCK TOTAL SOLID	2.0 hr.	NOTE 4	3.04	-	375

NOTE:
1. Maximum height guideline for block is 5040 (non-load bearing), 2800 (load bearing)
2. Refer to floor plans for interior partition type
3. Refer to Structural Engineering drawings for lateral support details and maximum height spans.
4. Provide mineral wool fire-stopping and smoke-seal caulk at gap between top of block and underside of structure above.
5. Continuity of fire-separation to be verified prior to covering/concealing in any way.

FIRE-RATING:
6a. N.B.C. 2010 Table D-2.1.1 for Type S or N Concrete (O.B.C. 2012 SB-2 Table 2.1.1 for Type S or N Concrete)
6b. ULC 12005 - Type LD-205 Concrete, ULC tested suppliers ONLY (2 hr. F.R.R).

STOREFRONT CURTAINWALL SYSTEM
(PRE-FINISHED METAL SPANDREL PANEL)
100 SEMI-RIGID INSULATION MIN. R.S.I. 3.04
GALVANIZED METAL BACK PAN FULLY SEALED TO PROVIDE AIR/VAPOUR BARRIER
190 CONCRETE BLOCK

TYP.		F.R.R.	Nom.	R.S.I.	S.T.C.	NOM. THICKNESS
W4_B8	STOREFRONT METAL PANEL CURTAINWALL SYSTEM ON 190 CONCRETE BLOCK	2.0 hr.	NOTE 4	3.04	-	425

NOTE:
1. Maximum height guideline for block is 5040 (non-load bearing), 2800 (load bearing)
2. Refer to specifications for thickness and type of glazing
3. Refer to floor plans for interior partition type
4. Refer to Structural Engineering drawings for lateral support details and maximum height spans.
5. Provide mineral wool fire-stopping and smoke-seal caulk at gap between top of block and underside of structure above.
6. Continuity of fire-separation to be verified prior to covering/concealing in any way.

FIRE-RATING:
7. N.B.C. 2010 Table D-2.1.1 for Type S or N Concrete (O.B.C. 2012 SB-2 Table 2.1.1 for Type S or N Concrete)

STOREFRONT SINGLE GLAZED CURTAINWALL SYSTEM
(SEALED SPANDREL GLASS SHADOW BOX UNIT)
100 SEMI-RIGID INSULATION MIN. R.S.I. 3.04
GALVANIZED METAL BACK PAN FULLY SEALED TO PROVIDE AIR/VAPOUR BARRIER
140 CONCRETE BLOCK

TYP.		F.R.R.	Nom.	R.S.I.	S.T.C.	NOM. THICKNESS
W4_B7	STOREFRONT METAL PANEL CURTAINWALL SYSTEM ON 140 CONCRETE BLOCK TOTAL SOLID	2.0 hr.	NOTE 4	3.04	-	375

NOTE:
1. Maximum height guideline for block is 5040 (non-load bearing), 2800 (load bearing)
2. Refer to specifications for thickness and type of glazing
3. Refer to floor plans for interior partition type
4. Refer to Structural Engineering drawings for lateral support details and maximum height spans.
5. Provide mineral wool fire-stopping and smoke-seal caulk at gap between top of block and underside of structure above.
6. Continuity of fire-separation to be verified prior to covering/concealing in any way.

FIRE-RATING:
7a. N.B.C. 2010 Table D-2.1.1 for Type S or N Concrete (O.B.C. 2012 SB-2 Table 2.1.1 for Type S or N Concrete)
7b. ULC 12005 - Type LD-205 Concrete, ULC tested suppliers ONLY (2 hr. F.R.R).

STOREFRONT SINGLE GLAZED CURTAINWALL SYSTEM
(SEALED SPANDREL GLASS SHADOW BOX UNIT)
100 SEMI-RIGID INSULATION MIN. R.S.I. 3.04
GALVANIZED METAL BACK PAN FULLY SEALED TO PROVIDE AIR/VAPOUR BARRIER
190 CONCRETE BLOCK

TYP.		F.R.R.	Nom.	R.S.I.	S.T.C.	NOM. THICKNESS
W4_B6	STOREFRONT SPANDREL GLASS CURTAINWALL SYSTEM ON 190 CONCRETE BLOCK	2.0 hr.	NOTE 4	3.04	-	425

NOTE:
1. Maximum height guideline for block is 5040 (non-load bearing), 2800 (load bearing)
2. Refer to specifications for thickness and type of glazing
3. Refer to floor plans for interior partition type
4. Refer to Structural Engineering drawings for lateral support details and maximum height spans.
5. Provide mineral wool fire-stopping and smoke-seal caulk at gap between top of block and underside of structure above.
6. Continuity of fire-separation to be verified prior to covering/concealing in any way.

FIRE-RATING:
7. N.B.C. 2010 Table D-2.1.1 for Type S or N Concrete (O.B.C. 2012 SB-2 Table 2.1.1 for Type S or N Concrete)

STOREFRONT SINGLE GLAZED CURTAINWALL SYSTEM
(SEALED SPANDREL GLASS SHADOW BOX UNIT)
100 SEMI-RIGID INSULATION MIN. R.S.I. 3.04
GALVANIZED METAL BACK PAN FULLY SEALED TO PROVIDE AIR/VAPOUR BARRIER
140 CONCRETE BLOCK

TYP.		F.R.R.	Nom.	R.S.I.	S.T.C.	NOM. THICKNESS
W4_B5	STOREFRONT SPANDREL GLASS CURTAINWALL SYSTEM ON 140 CONCRETE BLOCK TOTAL SOLID	2.0 hr.	NOTE 4	3.04	-	375

NOTE:
1. All form tie holes to be filled (refer to specifications for detail)
2. Refer to floor plans for interior partition type

STOREFRONT CURTAINWALL SYSTEM
(PRE-FINISHED METAL LOUVER)
100 SEMI-RIGID INSULATION MIN. R.S.I. 3.04
GALVANIZED METAL BACK PAN FULLY SEALED TO PROVIDE AIR/VAPOUR BARRIER
STRUCTURAL CONCRETE (SEE STRUCTURAL DRAWINGS)
FOR INTERIOR FINISH REFER TO ROOM FINISH SCHEDULE

TYP.		F.R.R.	Nom.	R.S.I.	S.T.C.	NOM. THICKNESS
W4_A5	STOREFRONT METAL LOUVER CURTAINWALL SYSTEM	-	-	3.04	-	430

NOTE:
1. All form tie holes to be filled (refer to specifications for detail)
2. Refer to floor plans for interior partition type

STOREFRONT CURTAINWALL SYSTEM
(PRE-FINISHED METAL SPANDREL PANEL)
100 SEMI-RIGID INSULATION MIN. R.S.I. 3.04
GALVANIZED METAL BACK PAN FULLY SEALED TO PROVIDE AIR/VAPOUR BARRIER
STRUCTURAL CONCRETE (SEE STRUCTURAL DRAWINGS)
FOR INTERIOR FINISH REFER TO ROOM FINISH SCHEDULE

TYP.		F.R.R.	Nom.	R.S.I.	S.T.C.	NOM. THICKNESS
W4_A4	STOREFRONT METAL PANEL CURTAINWALL SYSTEM ON STRUCTURAL CONCRETE	2.0 hr.	-	3.04	-	430

NOTE:
1. All form tie holes to be filled (Refer to specifications for details)
2. Refer to specifications for thickness and type of glass
3. Refer to floor plans for interior partition type

STOREFRONT SINGLE GLAZED CURTAINWALL SYSTEM
(SEALED SPANDREL GLASS SHADOW BOX UNIT)
100 SEMI-RIGID INSULATION MIN. R.S.I. 3.04
GALVANIZED METAL BACK PAN FULLY SEALED TO PROVIDE AIR/VAPOUR BARRIER
STRUCTURAL CONCRETE (SEE STRUCTURAL DRAWINGS)

TYP.		F.R.R.	Nom.	R.S.I.	S.T.C.	NOM. THICKNESS
W4_A3	STOREFRONT SPANDREL GLASS CURTAINWALL SYSTEM ON STRUCTURAL CONCRETE	2.0 hr.	-	3.04	-	430

NOTE:
1. Refer to specifications for thickness and type of glazing

STOREFRONT DOUBLE GLAZED CURTAINWALL SYSTEM
(SEALED VISION GLASS UNIT)

TYP.		F.R.R.	Nom.	R.S.I.	S.T.C.	NOM. THICKNESS
W4_B7	STOREFRONT CURTAINWALL SYSTEM	-	-	-	-	185

Window Wall Construction — W3 / A8-03

SCALE N.T.S.

NOTE:
1. Max. height = 4264 with CH stud 400 CH-34 (L.040)
2. For interior finish refer to room finish schedule
3. Provide fire-sealant around entire perimeter of wall at junction between stud track and floor/ceiling, both sides of wall.
4. Refer to ULC-W-402, or ULC-W-48A for complete assembly requirements.

WINDOW WALL ASSEMBLY (PRE-FINISHED ARCHITECTURAL LOUVER SPANDREL PANEL) WITH 50 SEMI-RIGID INSULATION MIN. R.S.I. 1.12 AND GALVANIZED METAL BACKPAN
MODIFIED 1 HOUR RATED SHAFTWALL (P11) (1) WHERE FIRE RATING IS NOTED ON FLOOR PLANS
75 MINERAL WOOL THERMAL INSULATION BLANKETS MIN. R.S.I 2.28
VAPOUR BARRIER
13 GYPSUM BOARD FULLY SEALED TO PROVIDE AIR BARRIER

TYP.		F.R.R.	NOTE	R.S.I.	S.T.C.	NOM. THICKNESS
W3_C6	FIRE RATED ARCHITECTURAL METAL LOUVER ON SPANDREL PANEL	1.0 hr.	NOTE 4	3.8	-	245

NOTE:
1. For interior finish refer to room finish schedule

WINDOW WALL ASSEMBLY (PRE-FINISHED METAL LOUVER) WITH 50 SEMI-RIGID INSULATION MIN. R.S.I. 1.12 AND GALVANIZED METAL BACKPAN
64 METAL STUDS @ 400 "C
R5 THERMAL INSULATION BATTS MIN. R.S.I. 2.38
VAPOUR BARRIER
13 GYPSUM BOARD FULLY SEALED TO PROVIDE AIR BARRIER

TYP.		F.R.R.	Nom.	R.S.I.	S.T.C.	NOM. THICKNESS
W3_C7	ARCHITECTURAL METAL LOUVER ON SPANDREL PANEL	-	-	3.8	-	230

NOTE:
1. For interior finish refer to room finish schedule

WINDOW WALL ASSEMBLY (PRE-FINISHED ARCHITECTURAL METAL LOUVER) WITH 50 SEMI-RIGID INSULATION MIN. R.S.I. 1.12 AND GALVANIZED METAL BACKPAN
64 METAL STUDS @ 400 "C
R5 THERMAL INSULATION BATTS MIN. R.S.I. 2.38
VAPOUR BARRIER
13 GYPSUM BOARD FULLY SEALED TO PROVIDE AIR BARRIER

TYP.		F.R.R.	NOTE	R.S.I.	S.T.C.	NOM. THICKNESS
W3_C5	FIRE RATED METAL SPANDREL PANEL	1.0 hr.	NOTE 4	3.8	-	245

NOTE:
1. Max. height = 4264 with CH stud 400 CH-34 (L.040)
2. For interior finish refer to room finish schedule
3. Provide fire-sealant around entire perimeter of wall at junction between stud track and floor/ceiling, both sides of wall.
4. Refer to ULC-W-402, or ULC-W-48A for complete assembly requirements.

WINDOW WALL ASSEMBLY (PRE-FINISHED METAL SPANDREL PANEL) WITH 50 SEMI-RIGID INSULATION MIN. R.S.I. 1.12 AND GALVANIZED METAL BACKPAN
MODIFIED 1 HOUR RATED SHAFTWALL (P11) (1) WHERE FIRE RATING IS NOTED ON FLOOR PLANS
75 MINERAL WOOL THERMAL INSULATION BLANKET MIN. R.S.I. 2.28
VAPOUR BARRIER
GYPSUM BOARD FULLY SEALED TO PROVIDE AIR BARRIER

TYP.		F.R.R.	Nom.	R.S.I.	S.T.C.	NOM. THICKNESS
W3_C4	METAL SPANDREL PANEL	-	-	3.8	-	230

NOTE:
1. For interior finish refer to room finish schedule

WINDOW WALL ASSEMBLY (PRE-FINISHED METAL SPANDREL PANEL) WITH 50 SEMI-RIGID INSULATION MIN. R.S.I. 1.12 AND GALVANIZED METAL BACKPAN
64 METAL STUDS @ 400 "C
R5 THERMAL INSULATION BATTS MIN. R.S.I. 2.38
VAPOUR BARRIER
13 GYPSUM BOARD FULLY SEALED TO PROVIDE AIR BARRIER

TYP.		F.R.R.	NOTE	R.S.I.	S.T.C.	NOM. THICKNESS
W3_C2	FIRE RATED GLASS SPANDREL PANEL	1.0 hr.	NOTE 4	3.8	-	245

NOTE:
1. For interior finish refer to room finish schedule

WINDOW WALL ASSEMBLY (BACK-PAINTED SPANDREL GLASS) WITH 50 SEMI-RIGID INSULATION MIN. R.S.I. 1.12 AND GALVANIZED METAL BACKPAN
64 METAL STUDS @ 400 "C
VAPOUR BARRIER
13 GYPSUM BOARD FULLY SEALED TO PROVIDE AIR BARRIER

TYP.		F.R.R.	Nom.	R.S.I.	S.T.C.	NOM. THICKNESS
W3_C1	GLASS SPANDREL PANEL	-	-	3.8	-	230

NOTE:
1. Maximum height guideline for block is 5040 (non-load bearing), 2800 (load bearing)
2. Refer to floor plans for interior partition type
3. Refer to Structural Engineering drawings for lateral support details and maximum height spans.
4. Provide mineral wool fire-stopping and smoke-seal caulk at gap between top of block and underside of structure above.
5. Continuity of fire-separation to be verified prior to covering/concealing in any way.

FIRE-RATING:
6. N.B.C. 2010 Table D-2.1.1 for Type S or N Concrete (O.B.C. 2012 SB-2 Table 2.1.1 for Type S or N Concrete)

WINDOW WALL ASSEMBLY (PRE-FINISHED ARCHITECTURAL METAL LOUVER) WITH 50 SEMI-RIGID INSULATION MIN. R.S.I. 1.12 AND GALVANIZED METAL BACKPAN
120 SEMI-RIGID INSULATION MIN. R.S.I. 3.8
ARIVAPOUR BARRIER
140 CONCRETE BLOCK

TYP.		F.R.R.	Nom.	R.S.I.	S.T.C.	NOM. THICKNESS
W3_B7	ARCHITECTURAL METAL LOUVER ON 140 CONCRETE BLOCK TOTAL SOLID	1.0 hr.	-	3.8	-	390

Window Wall Construction — W3 / A8-03

SCALE N.T.S.

NOTE:
1. Maximum height guideline for block is 5040 (non-load bearing), 2800 (load bearing)
2. Refer to floor plans for interior partition type
3. Refer to Structural Engineering drawings for lateral support details and maximum height spans.
4. Provide mineral wool fire-stopping and smoke-seal caulk at gap between top of block and underside of structure above.
5. Continuity of fire-separation to be verified prior to covering/concealing in any way.

FIRE-RATING:
6. N.B.C. 2010 Table D-2.1.1 for Type S or N Concrete (O.B.C. 2012 SB-2 Table 2.1.1 for Type S or N Concrete)

WINDOW WALL ASSEMBLY (PRE-FINISHED ARCHITECTURAL METAL LOUVER) WITH 50 SEMI-RIGID INSULATION MIN. R.S.I. 1.12 AND GALVANIZED METAL BACKPAN
120 SEMI-RIGID INSULATION MIN. R.S.I. 3.8
ARIVAPOUR BARRIER
140 CONCRETE BLOCK

TYP.		F.R.R.	Nom.	R.S.I.	S.T.C.	NOM. THICKNESS
W3_B4	METAL SPANDREL PANEL ON 140 CONCRETE BLOCK TOTAL SOLID	1.0 hr.	-	3.8	-	390

NOTE:
1. Maximum height guideline for block is 5040 (non-load bearing), 2800 (load bearing)
2. Refer to floor plans for interior partition type
3. Refer to Structural Engineering drawings for lateral support details and maximum height spans.
4. Provide mineral wool fire-stopping and smoke-seal caulk at gap between top of block and underside of structure above.
5. Continuity of fire-separation to be verified prior to covering/concealing in any way.

FIRE-RATING:
6. N.B.C. 2010 Table D-2.1.1 for Type S or N Concrete (O.B.C. 2012 SB-2 Table 2.1.1 for Type S or N Concrete)

WINDOW WALL ASSEMBLY (BACK-PAINTED SPANDREL GLASS) WITH 50 SEMI-RIGID INSULATION MIN. R.S.I. 1.12 AND GALVANIZED METAL BACKPAN
120 SEMI-RIGID INSULATION MIN. R.S.I. 3.8
ARIVAPOUR BARRIER
140 CONCRETE BLOCK

TYP.		F.R.R.	Nom.	R.S.I.	S.T.C.	NOM. THICKNESS
W3_B1	GLASS SPANDREL PANEL ON 140 CONCRETE BLOCK TOTAL SOLID	1.0 hr.	-	3.8	-	390

NOTE:
1. Maximum height guideline for block is 5040 (non-load bearing), 2800 (load bearing)
2. Refer to floor plans for interior partition type
3. Refer to Structural Engineering drawings for lateral support details and maximum height spans.
4. Provide mineral wool fire-stopping and smoke-seal caulk at gap between top of block and underside of structure above.
5. Continuity of fire-separation to be verified prior to covering/concealing in any way.

FIRE-RATING:
6. N.B.C. 2010 Table D-2.1.1 for Type S or N Concrete (O.B.C. 2012 SB-2 Table 2.1.1 for Type S or N Concrete)

WINDOW WALL ASSEMBLY (PRE-FINISHED ARCHITECTURAL METAL LOUVER) WITH 50 SEMI-RIGID INSULATION MIN. R.S.I. 1.12 AND GALVANIZED METAL BACKPAN
120 SEMI-RIGID INSULATION MIN. R.S.I. 3.8
ARIVAPOUR BARRIER
140 CONCRETE BLOCK

TYP.		F.R.R.	Nom.	R.S.I.	S.T.C.	NOM. THICKNESS
W3_A3	ARCHITECTURAL METAL LOUVER ON STRUCTURAL CONCRETE	2.0 hr.	-	3.8	-	450 MIN.

NOTE:
1. All form tie holes to be filled (Refer to specifications for detail)
2. Refer to floor plans for interior partition type

WINDOW WALL ASSEMBLY (PRE-FINISHED METAL LOUVER) WITH 50 SEMI-RIGID INSULATION MIN. R.S.I. 1.12 AND GALVANIZED METAL BACKPAN
ARIVAPOUR BARRIER
STRUCTURAL CONCRETE (REFER TO STRUCTURAL DRAWINGS)

TYP.		F.R.R.	Nom.	R.S.I.	S.T.C.	NOM. THICKNESS
W3_A2	METAL SPANDREL PANEL ON CONCRETE	2.0 hr.	-	3.8	-	450 MIN.

NOTE:
1. All form tie holes to be filled (Refer to specifications for detail)
2. Refer to floor plans for interior partition type

WINDOW WALL ASSEMBLY (BACK-PAINTED SPANDREL GLASS) WITH 50 SEMI-RIGID INSULATION MIN. R.S.I. 1.12 AND GALVANIZED METAL BACKPAN
ARIVAPOUR BARRIER
STRUCTURAL CONCRETE (REFER TO STRUCTURAL DRAWINGS)

TYP.		F.R.R.	Nom.	R.S.I.	S.T.C.	NOM. THICKNESS
W3_A1	GLASS SPANDREL PANEL ON CONCRETE	2.0 hr.	-	3.8	-	450 MIN.

NOTE:
1. Refer to specifications for thickness and type of glazing

WINDOW WALL ASSEMBLY DOUBLE GLAZED INSULATED GLASS WITH PRE-FINISHED ALUMINUM WINDOW WALL SYSTEM

TYP.		F.R.R.	Nom.	R.S.I.	S.T.C.	NOM. THICKNESS
W3_*	VISION PANEL	-	-	-	-	120

NOTE:
1. For interior finish refer to room finish schedules

90 MASONRY UNIT (SEE EXTERIOR MATERIAL FINISH SCHEDULE)
25 AIR SPACE
50 SEMI-RIGID INSULATION MIN. R.S.I. 1.40
VAPOUR PERME