



SITE INSTRUCTION

SI – 11

To:

Vince Mirachi	Tridel
Bruno Giancola	Tridel
Chadi Loza	Tridel
Carlos Antunes	Kirkor Architects & Planners
Christina Lee	Kirkor Architects & Planners
Babak Baradaran- Seyed	Stephenson Engineering Ltd.
Colin Huston	Stephenson Engineering Ltd.
Al Medeiros	MCW (Electrical)
Sunanda Perera	MCW (Electrical)
Mark Furtado	MCW (Mechanical)
Ryan Houghton	MCW (Site)
Robert Severini	Mirenda
Remus Muntan	Deltera
Salvatore Cavarrette	Deltera
Aquavista Site Office	Deltera

From: **Howard Tuchman** KIRKOR | Architects + PlannersDate: **September 7, 2017**Project: **Aquavista – (Bayside Block 3 R3 & R4, Merchants Wharf)
263 Queens Quay East, Toronto**Project No.: **13-148**

Site instructions are issued only for the purpose of recording any clarification or interpretation of the contract documents or giving direction on problems resulting from field conditions. These instructions are subject to the provisions of the contract documents and unless stated herein and specifically co-authorized by the Client, will not affect the contract. Should the Contractor require a change in the contract price or project schedule, he/she shall submit to the "Client" within ten (10) days of the date hereof, an itemized proposal. If the proposal is accepted by the Client, this site instruction will be superseded by a Change Order issued by the Client.

No.	Description	Reference Drawings
	<i>This site instruction deals with the change of door swing direction of door 104 at Level 1 Mail Room. Revision of granite exterior finishes 2A & 2B on the Exterior Finishes Legend. Removal of the heating cables above the Gas Regulators at Level 1. Revision of wall type around the male and female retail shower on Level P1.</i>	
.1	Revised the door swing direction of the Mail Room door (Door 104) on Level 1.	A2-06, A7-21
.2	Revised the colour and finish of the granite exterior finishes 2A & 2B on the Exterior Finishes Legend. Colour: Cambrian Black Finish: Honed	A4-01, A4-02, A4-03

20 De Boers Dr. # 400 Toronto ON M3J 0H1
TEL 416 665 6060 kirkorarchitects.com

CLIFFORD KORMAN
BES / B.ARCH / QAA / RAIC /
MAIBC / OPPI / RPP / MCIP /
NCARB / AIA / AAA

STEVEN KIRSHENBLATT
BES / B.ARCH / QAA / RAIC /
MAIBC / LEED AP

CARLOS ANTUNES
B.TECH (ARCH) / M.ARCH /
QAA / RAIC

DAVID BUTTERWORTH
BA (HONS) ARCH / DIP ARCH
(OXFORD) / QAA / ARB / RIBA /
RAIC

BRENT WHITBY
BES / M.ARCH / QAA /
MAA / AAA / RAIC

.3	Removed the heating cables on the ceiling of gas regulator room on Level 1. Added a new ceiling assembly (S1-H) to Sheet A8-02 .	A7-15, A7-02, A8-02
.4	Revised the wall type surrounding the male and female retail shower on Level P1 with wall type P2.B3 with 1.5 hour F.R.R.	A2-04, A2-05, A3-01
N.B.	All referenced drawings are available for immediate download from the KIRKOR/Newforma InfoExchange for a period of 60 days. All referenced drawings have been uploaded to the Astley Gilbert DFS for immediate printing / access.	

End of Site Instruction