



SITE INSTRUCTION

SI – 15

To:

Vince Mirachi	Tridel
Bruno Giancola	Tridel
Chadi Loza	Tridel
Carlos Antunes	Kirkor Architects & Planners
Christina Lee	Kirkor Architects & Planners
Babak Baradaran- Seyed	Stephenson Engineering Ltd.
Colin Huston	Stephenson Engineering Ltd.
Al Medeiros	MCW (Electrical)
Sunanda Perera	MCW (Electrical)
Mark Furtado	MCW (Mechanical)
Ryan Houghton	MCW (Site)
Robert Severini	Mirenda
Remus Muntan	Deltera
Salvatore Cavarrette	Deltera
Aquavista Site Office	Deltera

From: **Howard Tuchman** KIRKOR | Architects + PlannersDate: **October 04, 2017**Project: **Aquavista – (Bayside Block 3 R3 & R4, Merchants Wharf)
263 Queens Quay East, Toronto**Project No.: **13-148**

Site instructions are issued only for the purpose of recording any clarification or interpretation of the contract documents or giving direction on problems resulting from field conditions. These instructions are subject to the provisions of the contract documents and unless stated herein and specifically co-authorized by the Client, will not affect the contract. Should the Contractor require a change in the contract price or project schedule, he/she shall submit to the "Client" within ten (10) days of the date hereof, an itemized proposal. If the proposal is accepted by the Client, this site instruction will be superseded by a Change Order issued by the Client.

No.	Description	Reference Drawings
	<i>This site instruction deals with revision to sliding door in suite 1103, revision to shadow box window along the west elevation, and clarification to rough opening for doors on the P1 level. It also revised Level 11 Slab Edge drawing to include In-slab ductwork for Suite PH18 on Level 10.</i>	
.1	Revise exterior sliding door to fixed window wall at the 11 th level terrace for suite 1103 at the southwest wall. Provide vision glass as indicated on Detail 26/A4-23 .	A2-17, A3-25, A4-23
.2	Revise shadow box window to metal louvers at ground level between gridlines 9 & 12 as per Detail 11/ A6-06 .	A4-02, A4-06
.3	Clarification and modify interior window screen for type SC-12 and SC-13 in coordination with previously revised door schedule.	A8-06

20 De Boers Dr. # 400 Toronto ON M3J 0H1
TEL 416 665 6060 kirkorarchitects.com

CLIFFORD KORMAN
BES / B.ARCH / QAA / RAIC /
MAIBC / OPPI / RPP / MCIP /
NCARB / AIA / AAA

STEVEN KIRSHENBLATT
BES / B.ARCH / QAA / RAIC /
MAIBC / LEED AP

CARLOS ANTUNES
B.TECH (ARCH) / M.ARCH /
QAA / RAIC

DAVID BUTTERWORTH
BA (HONS) ARCH / DIP ARCH
(OXFORD) / QAA / ARB / RIBA /
RAIC

BRENT WHITBY
BES / M.ARCH / QAA /
MAA / AAA / RAIC

.4	Revised the Level 11 Slab Edge drawing to include the In-slab ductwork for Suite PH18 on the Level 10.	A9-56, A9-58
N.B.	All referenced drawings are available for immediate download from the KIRKOR/Newforma InfoExchange for a period of 60 days. All referenced drawings have been uploaded to the Astley Gilbert DFS for immediate printing / access.	

End of Site Instruction