



MCW Consultants Ltd.

Addendum

Date: Dec. 10, 2015

Queen's Quay Terminal
207 Queen's Quay West, Suite 615
Toronto, Ontario M5J 1A7

Phone (416) 598-2920
Fax (416) 598-5394
www.mcw.com

Project Name: AQUAVISTA - Bayside
Client: TRIDEL Corporation
To: TRIDEL Corporation
Attention: Chadi Loza
Fax number: -

Project No.: 8489D
ADD No.: E 001
Page No.: 1 of 3+ Attached
Office: Toronto
From: Sunanda Perera
Tao Li

Distribution: Vince Mirarchi –TRIDEL
Solvera Gomes TRIDEL
Christina Lee -KIRKOR
Al Medeiros –MCW
Michael Hunter-MCW
Mitch Gascoyne-MCW
Mark Furtado-MCW
Sarfraz H. Jaffrey-MCW

In accordance with the drawings and specifications, provide in the tender all costs required to complete the work including items as listed below:

Title: Various Electrical Changes.

Specification:

Spec	Issued	Items
Panel 'P-2P1RCAP' 'P-2P1RCPE' 'P-2RRCPW' 'P-2ERRCPE' 'P-2RRCPE' 'P-2P1MRAP' 'P-2RRAP' 'P-2ERRAP' 'P-21MCRP'	Yes	Panel schedule has been revised to reflect the device/equipment addition.

Electrical:

Drawing No.	Drawing Issued	Items
E0-01	Yes	Electrical legend has been updated with CO detector and exit sign.
E1-01	Yes	- Add circuit for future car wash controller as shown. - Add fire alarm speaker/strobes in mechanical room as shown.
E1-02	Yes	- Add fire alarm speaker/strobes in mechanical room as shown. - Add receptacles in mechanical room and irrigation room.
E1-03	Yes	Add door opener in BF WC as shown.

		- Add one receptacle in AV ROOM as shown. - Revise fire alarm speaks to speaker/strobe as shown.
E2-01A	Yes	- Add fire alarm pull stations as shown. - Add door opener in retail area as shown.
E2-01B	Yes	Revise electrical devices to match architectural layout in Commercial Elevator Lobby as shown.
E2-02A	Yes	- Add receptacles in mechanical room for future use as shown. - Add fire alarm speaker/strobes in mechanical room as shown. - Add one emergency kill switch on the door between Retail Mech. Room and Retail Make-up Unit Room as shown. - Revise electrical devices to match architectural layout in retail Electrical Room as shown.
E2-03A	Yes	- Revise electrical devices to match architectural layout as shown. - Revise heat traced path area as shown. - Add lights and receptacles on residential terrace as shown.
E2-03B	Yes	- Revise electrical devices to match architectural layout as shown. - Add lights and receptacles on residential terrace as shown.
E2-04A E2-04B E2-05A E2-05B E2-06A E2-06B E2-07A E2-07B E2-08A E2-08B E2-09A E2-09B E2-10A E2-10B E2-11A E2-11B E2-12A E2-12B E2-13A E2-13B	Yes	- Revise electrical devices to match architectural layout as shown. - Revise electrical devices on floor plan to match riser as shown. - Add lights and receptacles on residential terrace as shown. - Add receptacles on residential balcony as shown.
E2-14A/14b	Yes	- Revise electrical devices in Stair 'Gx', 'H' & 'J' to match riser as shown. - Add fire alarm speaker/strobe in Artscape mechanical room (1309), mechanical rooms (1316) / (1322) and elevator machine rooms (1318) / (1310) / (1317) as shown. - Add exit signs on corridor (1320) as shown.
E2-15	Yes	Add window washing receptacles.



MCW Consultants Ltd.

Project Name: Aquavista
To: TRIDEL Corporation

Project No.: 8489D
ADD No.: E 001
Page No.: 3 of 3

E3-01-RC	Yes	Revise single line diagram with metering requirement.
E3-02RA	Yes	Revise single line diagram with metering requirement.
E3-03-CP/CR	Yes	Revise single line diagram with metering requirement.
E3-01 E3-02 E3-03	Yes	Add and delete metering equipment as shown.
E4-01	Yes	Delete corridor receptacles as shown.
E4-04	Yes	Revise fire alarm zone schedule as shown.
E5-02	Yes	Delete one detail drawing as shown.
E5-03	Yes	Add metering riser and schedules as shown.

ME SCHEDULE:

Drawing No.	Drawing Issued	Items
ME-15	Yes	Add three new details as shown.

Reason for Issue-Design complete.

End of ADD E-001