



MCW Consultants Ltd.

Site Instruction

Date: May 25, 2017

Queen's Quay Terminal
207 Queen's Quay West, Suite 615
Toronto, Ontario M5J 1A7

Phone (416) 598-2920
Fax (416) 598-5394
www.mcw.com

Project Name: AQUAVISTA - Bayside
Client: TRIDEL Corporation
To: TRIDEL Corporation
Attention: Chadi Loza
Fax number: -

Project No.: 8489D
SI No.: E 012
Page No.: 1 of 2+ 9 attached
Office: Toronto
From: Sunanda Perera
Tao Li

Distribution: Vince Mirarchi –TRIDEL
Chadi Loza - TRIDEL
Christina Lee -KIRKOR
Al Medeiros –MCW
Michael Hunter-MCW
Mark Furtado-MCW
Sarfraz H. Jaffrey-MCW

Provide itemized labour, equipment and material costs for Work listed below. Do not proceed with any of the listed Work prior to issuance of signed Change Order.

Title: Update electrical drawings to match blackline drawings – Level 11 & Up.

Specification:

Spec	Issued	Items
		• N/A

Electrical:

Drawing No.	Drawing Issued	Items
E2-09A	Yes	Relocate suite panel in suite 809 as shown.
E2-11A	Yes	- Relocate power connections for kitchen equipment in suite 1027 as shown. - Revise kitchen area electrical devices in suite 1019 as shown.
E2-11B	Yes	- Add type 'DLX3' (Qty-1) lighting fixture in corridor as shown. - Create separate drawing for suite 1015. The new drawing shall be issued with separate instruction.
E2-12A E2-12B	Yes	- Provide door contacts at all doors to suite terrace. - Add power receptacles and telecomm outlets as shown. - Delete floor mounted power receptacles and telephone outlet as shown. - Add type 'S1' lighting fixtures as shown. - Delete type 'S1', 'S2', 'S3', 'S4' and 'S9' lighting fixtures as shown. - Delete type 'X1' lighting fixtures as shown.
E2-13A E2-13B	Yes	- Add power receptacles and telecomm outlets as shown. - Delete floor mounted power receptacles and telephone outlet as shown.

		• Add type 'S1' lighting fixtures as shown. • Delete type 'S1', 'S2', 'S3' and 'S4' lighting fixtures as shown. • Delete type 'X1' lighting fixtures as shown. • Relocate elevator disconnect switch to elevator machine room in suite PH9 and PH12, and add smoke alarm in elevator machine room as shown.
E2-14A E2-14B	Yes	• Provide door contacts at all doors to suite terrace. • Add power receptacles and telecomm outlets as shown. • Delete floor mounted power receptacles and telephone outlet as shown. • Add type 'S1' lighting fixtures as shown. • Delete type 'S1', 'S2' and 'S8' lighting fixtures as shown. • Delete type 'X1' lighting fixtures as shown. • Add power connection to EF-C in suite PH16 power room as shown. • Revise electrical devices location to match architectural background in suite PH10 as shown.

ME Schedule:

Drawing No.	Drawing Issued	Items
		N/A

Changes are not limited to the above listed items. Refer to drawings for the complete changes under this SI. All the changes are bubbled.

Reason for Issue - Suite blackline Coordination/Owner request.

End of SI-E012