



MCW Consultants Ltd.

Site Instruction

Date: October 11, 2017

Queen's Quay Terminal
207 Queen's Quay West, Suite 615
Toronto, Ontario M5J 1A7

Phone (416) 598-2920
Fax (416) 598-5394
www.mcw.com

Project Name: AQUAVISTA - Bayside

Client: TRIDEL Corporation

To: TRIDEL Corporation

Attention: Chadi Loza

Fax number: -

Distribution: Vince Mirarchi -TRIDEL
Chadi Loza - TRIDEL
Christina Lee -KIRKOR
Al Medeiros -MCW
Michael Hunter-MCW
Mark Furtado-MCW
Sarfraz H. Jaffrey-MCW

Project 8489D

No.:

SI No.: E 030

Page No.: 1 of 1+ 1 attached

Office: Toronto

From: Sunanda Perera
Tao Li

Provide itemized labour, equipment and material costs for Work listed below. Do not proceed with any of the listed Work prior to issuance of signed Change Order.

Title: Power Connections to Motorized Dampers

Specification:

Spec	Issued	Items
		N/A

Electrical:

Drawing No.	Drawing Issued	Items
E1-06	Yes	- Relocate exhaust fan power connections as shown to match mechanical drawings. - Connect added motorized dampers using spare circuits, 15A/1P in panels '2P1RCMW', '2P1RCME', '21MCRM' and '2E1MCRP2'.

ME Schedule:

Drawing No.	Drawing Issued	Items
		N/A.

Reason for Issue – Design Coordinate with Mechanical SI-M016.

End of SI-E030

