



POWER AND COMMUNICATION NOTATIONS

1. POWER AND COMMUNICATION DRAWINGS TO BE USED FOR LOCAL PURPOSES ONLY. REFER TO ELECTRICAL ENGINEERING DRAWINGS FOR DETAILS, SPECIFICATIONS AND REQUIREMENTS.
2. ELECTRICAL AND COMMUNICATION WORK TO COMPLY WITH THE REQUIREMENTS OF THE BUILDING LAWFULLS AND AUTHORITIES HAVING JURISDICTION.
3. CONTRACTOR TO REPORT DISCREPANCIES BETWEEN ELECTRICAL AND DESIGN DRAWINGS TO THE ARCHITECT AND ELECTRICAL ENGINEER IMMEDIATELY UPON DISCOVERY OF MISMATCH.
4. SUBMIT REQUIRED CHANGES TO THE ARCHITECT FOR APPROVAL PRIOR TO COMMENCEMENT OF WORK.
5. DIMENSIONS OF SERVICES TAKEN AT THE POINT OF THE SERVICE OR CORD FROM THE SERVICE UNITS, UNLESS OTHERWISE NOTED.
6. DIMENSIONS FROM A PARTITION AND TAKEN FROM FACE OF PARTITION TO CENTRE OF THE SERVICE OR GROUP OF SERVICES, UNLESS OTHERWISE NOTED.
7. DIMENSIONS FROM THE PERIMETER OF THE FOLLOWING ARE TAKEN FROM FACE OF THE PARTITION, UNLESS BALANCE IS OTHERWISE NOTED TO CENTRE OF THE GROUP OF SERVICES, UNLESS OTHERWISE NOTED.
8. REFER TO ENGINEERING DRAWINGS FOR SPECIFICATION OF CORD RATES, RESPECTABLE FOR EACH SERVICE. REFER TO REFER TO DRAWING TO LOCATING RATES.
9. WHERE POWER AND COMMUNICATION SERVICES ARE ADJACENT ON PLAIN, CANOE COROR PLATE SHALL BE USED.
10. CONTRACTOR TO MAKE SURE THAT TRACES HAVE COMPLETED THEIR PORTION OF THE WORK BEFORE BEARING UP BOTH SIDES OF THE STUDIOS. THIS TO INCLUDE INSTRUCTIONS AS REQUIRED BY THE ARCHITECT AND PROVIDED BY BALANCE AND BUILDING CODES.
11. SUBMIT SCHEDULE OF WORK TO BE COMPLETED TO COORDINATE BETWEEN POWER AND TELEPHONE OUTLETS WITHOUT INTERRUPTION.
12. STAGGER OUTLETS OCCURRING ON OPPOSITE SIDES OF THE SAME PARTITION TO MAINTAIN ACCESS TO THE OTHER SIDE.
13. FURNISHING SYSTEM FEEDS TO BE SUPPLIED BY SYSTEM PARTIAL MANUFACTURERS AND ELECTRICAL CONNECTION TO SYSTEMS BY ELECTRICAL CONTRACTOR.
14. CONTRACTOR TO SUPPLY, INSTALL, CONNECT AND VERIFY SECURITY ACCESS CONTROL EQUIPMENT. THIS INCLUDES THE SUPPLY AND INSTALLATION OF ACCESS CONTROLS, WIRING AND CABLEING AS PER SECURITY CONSULTANT'S SPECIFICATIONS AND DETAILS.
15. TYPICAL WALL OUTLETS TO BE MOUNTED AT 12" A.F.F.
16. REFER TO MECHANICAL & ELECTRICAL DESIGN DRAWINGS FOR SPECIFICATIONS.
17. ALL POWER SOURCES ON THIS PLAN TO BE COORDINATED AND APPROVED BY CLIENT FOR INSTALLATION AND PARALLELIZATION OF ALL WIRINGWORK WITH APPROVED SYSTEM.
18. CONTRACTOR SHALL CONFIRM ALL QUANTITIES PRIOR TO ORDERING.
19. CONTRACTOR IS RESPONSIBLE FOR:
 - PROVIDING ALL LIFTING EQUIPMENT, DATA LINES, PHONE LINES, ELECTRICAL, TELEVISION, ETC.
 - PROVIDING ALL EQUIPMENT OF LIFTING ELECTRICAL AS REQUIRED.
 - REMOVING ALL EXISTING TALL WIRE SYSTEMS UNDER EXISTING FLOORING IF REQUIRED.
20. CLIENT IS RESPONSIBLE FOR ALL PWS AND BEST WIRING.
21. THE ELECTRICAL CONTRACTOR MUST NOT THE SITE AND DO TAKE OFF ON QUANTITY AND MATERIALS REQUIRED BEFORE STARTING PROJECT. ALL DESIGNER NOTATIONS AND COMMENTS MUST BE IN CONFORMITY WITH SITE AND DESIGNER NOTATIONS. THERE ARE ANY DISCREPANCIES.

Issue:	
05 ISSUED FOR COORDINATION	16.01.11
06 ISSUED FOR CLIENT REVIEW	16.01.15
07 ISSUED FOR TENDER	16.03.18
09 ISSUED FOR ADDENDUM	17.01.27
10 ISSUED FOR CONSTRUCTION	17.06.19

[illegible]

AQUAVISTA
AT BAYSIDE TORONTO
1 EDGEWATER DRIVE, TORONTO ONTARIO

77 MOWAT AVENUE, SUITE 108
TORONTO, ONTARIO M6K 3E3 - CANADA
T + 1 416 531 2224
12 DESBROSSES STREET
NEW YORK, NEW YORK 10013 - USA
T + 1 212 392 4952

Drawing Title:
LEVEL 6
POWER AND
COMMUNICATION PLAN

Our Project Number:	
14008	
Designed By:	Detailed By:
DM,KR, VW,SG	DM,KR, VW,SG,BP

ID4.12