



VEHICULAR PARKING: 76 RETAIL  
 BICYCLE PARKING: 65 CONDO / 8 AFFORDABLE  
 LOCKERS: 28 CONDO

LEVEL P1  
 JUNE 3 2014

\*WHERE ARE THE  
 BOILER FWES +  
 PIPE SHAFTS!!

THIS ROOM  
 CANNOT BE  
 STACKED WITH  
 AFFORD. PUMP  
 ROOM. NEED  
 60m<sup>2</sup> AND  
 MIN 3m HIGH  
 SPACE

37m<sup>2</sup> is  
 OK

23m<sup>2</sup> is OK

AMENITY VENTILATION  
 60m<sup>2</sup> REQ'D