



## POWER AND COMMUNICATION NOTATIONS

1. POWER AND COMMUNICATION DRAWINGS TO BE USED FOR LOCAL PURPOSES ONLY. REFER TO ELECTRICAL ENGINEERING DRAWINGS FOR DETAILS, SPECIFICATIONS AND REQUIREMENTS.
2. ELECTRICAL AND COMMUNICATION WORK TO COMPLY WITH THE REQUIREMENTS OF THE BUILDING LAWFULLS AND AUTHORITIES HAVING JURISDICTION.
3. CONTRACTOR TO REPORT DISCREPANCIES BETWEEN ELECTRICAL AND DESIGN DRAWINGS TO THE ARCHITECT AND ELECTRICAL ENGINEER IMMEDIATELY UPON DISCOVERY OF MISTAKE.
4. SUBMIT REQUIRED CHANGES TO THE ARCHITECT FOR APPROVAL PRIOR TO COMMENCEMENT OF WORK.
5. DIMENSIONS OF SERVICES TAKEN AT THE POINT OF THE SERVICE OR GROUP OF SERVICES, UNLESS OTHERWISE NOTED.
6. DIMENSIONS FROM A PARTITION AND TAKEN FROM FACE OF PARTITION TO CENTRE OF THE SERVICE OR GROUP OF SERVICES, UNLESS OTHERWISE NOTED.
7. DIMENSIONS FROM THE PERIMETER OF THE FOLLOWING ARE TAKEN FROM FACE OF THE PARTITION, UNLESS BALANCE IS OTHERWISE NOTED TO CENTRE OF THE SERVICE OR GROUP OF SERVICES, UNLESS OTHERWISE NOTED.
8. REFER TO ENGINEERING DRAWINGS FOR SPECIFICATION OF COLOUR PLATE, RESPECTABLE FOR THE SAME. REFER TO THE DRAWING TO CENTRE OF THE FOLLOWING SERVICE.
9. WHERE POWER AND COMMUNICATION SERVICES ARE ADJACENT ON PLAIN, CANOE COVER PLATE SHALL BE USED.
10. CONTRACTOR TO MAKE SURE THAT TRACES HAVE COMPLETED THEIR PORTION OF THE WORK BEFORE BEARING UP BOTH SIDES OF THE STUDIOS THAT IT DOES NOT INCLUDE INCORPORATIONS AS REQUIRED BY THE DRAWING AND FROM PLUMBING AND BUILDING CODES.
11. SUBMIT SCHEDULE OF MATERIALS TO CONTRACTING BODY FOR APPROVAL PRIOR TO COMMENCEMENT OF WORK.
12. STAGGER OUTLETS OCCURRING ON OPPOSITE SIDES OF THE SAME PARTITION TO MAINTAIN BALANCE.
13. FURNISHING SYSTEM FEEDS TO BE SUPPLIED BY SYSTEM PLANT MANUFACTURERS AND ELECTRICAL CONNECTIONS TO BE SUPPLIED BY ELECTRICAL CONTRACTOR.
14. CONTRACTOR TO SUPPLY, INSTALL, CONNECT AND VERIFY SECURITY ACCESS CONTROL EQUIPMENT. THE SUPPLIER SHALL BE RESPONSIBLE FOR THE EQUIPMENT, INCLUDING WIRING AND CABLEING AS PER SECURITY CONSULTANT'S SPECIFICATIONS AND DETAILS.
15. TYPICAL WALL OUTLETS TO BE MOUNTED AT 12" A.F.F.
16. REFER TO MECHANICAL & ELECTRICAL DESIGN DRAWINGS FOR SPECIFICATIONS.
17. ALL POWER SOURCES ON THIS PLAN TO BE COORDINATED AND APPROVED BY CLIENT FOR INSTALLATION AND FABRICATION OF ANY WORKLOAD WITH APPROVED SYSTEMS.
18. CONTRACTOR SHALL CONFIRM ALL QUANTITIES PRIOR TO ORDERING.
19. CONTRACTOR IS RESPONSIBLE FOR:
  - PROVIDING ALL LIFTING DEVICES, DATA LINES, PHONE LINES, ELECTRICAL TYPINGS, ETC.
  - PROVIDING ALL EQUIPMENT OF EXISTING ELECTRICAL AS REQUIRED.
  - REMOVING ALL EXISTING TALL WIRE SYSTEMS UNDER EXISTING FLOORING IF REQUIRED.
20. CLIENT IS RESPONSIBLE FOR ALL PWS AND BEST WIRING.
21. THE ELECTRICAL CONTRACTOR MUST NOT THE SITE AND DO TAKE OFF ON QUANTITY AND MATERIALS REQUIRED BEFORE STARTING PROJECT. ALL DESIGNER NOTATIONS AND COMMENTS MUST BE IN CONFORMITY WITH CLIENT AND DESIGNER NOTATIONS. THERE ARE ANY DISCREPANCIES.

| Issue:                      |          |
|-----------------------------|----------|
| 05 ISSUED FOR COORDINATION  | 16.01.11 |
| 06 ISSUED FOR CLIENT REVIEW | 16.01.15 |
| 07 ISSUED FOR TENDER        | 16.03.18 |
| 09 ISSUED FOR ADDENDUM      | 17.01.27 |
| 10 ISSUED FOR CONSTRUCTION  | 17.06.19 |

[illegible]

ID4.11