



POWER AND COMMUNICATION NOTES

1. POWER AND COMMUNICATION DRAWINGS TO BE USED FOR LOCAL PURPOSES ONLY. REFER TO ELECTRICAL ENGINEERING DRAWINGS FOR DETAILS, SPECIFICATIONS AND REQUIREMENTS.
2. ELECTRICAL AND COMMUNICATION WORK TO COMPLY WITH THE REQUIREMENTS OF THE BUILDING LAWFULLS AND AUTHORITIES HAVING JURISDICTION.
3. CONTRACTOR TO REPORT DISCREPANCIES BETWEEN ELECTRICAL AND DESIGN DRAWINGS TO THE ARCHITECT AND ELECTRICAL ENGINEER IMMEDIATELY UPON DISCOVERY OF MISTAKE.
4. SUBMIT REQUIRED CHANGES TO THE ARCHITECT FOR APPROVAL PRIOR TO COMMENCEMENT OF WORK.
5. DIMENSIONS OF SERVICES TAKEN AT THE POINT OF THE SERVICE OR CORD FROM EXISTING SERVICE UNLESS OTHERWISE NOTED.
6. IMPOUNDS FROM A PARTITION ARE TAKEN FROM FACE OF PARTITION TO CENTRE OF THE SERVICE OR GROUP OF SERVICES, UNLESS OTHERWISE NOTED.
7. IMPOUNDS FROM THE PERIMETER OF THE WALLING ARE TAKEN FROM FACE OF THE WALLING TO THE BLIND BULGING OF THE WALLING TO CENTRE OF THE GROUP OF SERVICES, UNLESS OTHERWISE NOTED.
8. REFER TO ENGINEERING DRAWINGS FOR SPECIFICATION OF COOD PLATE, RESPECTABLE FOR EACH SERVICE. REFER TO THE DRAWING TO CENTRE OF THE BULGING RADIUS.
9. WHEN PIPING AND COMMUNICATION SERVICES ARE ADJACENT ON PLAN, CANOE CROSS PLATS SHALL BE USED.
10. CONTRACTOR TO MAKE SURE THAT TRACES HAVE COMPLETED THEIR PORTION OF THE WORK BEFORE BEARING UP BOTH SIDES OF THE STUDIOS THAT IT DOES INCLUDE IMPROVEMENTS AS REQUIRED BY THE DRAWING AND PROVISIONS, BLINDS AND BULGING CLIPS.
11. SUPERVISOR MUST INSURE THAT ALL SERVICES ARE CORRECTLY CONNECTED TO THE SYSTEMS WITHOUT INTERRUPTION.
12. STAGGER OUTLETS OCCURRING ON OPPOSITE SIDES OF THE SAME PARTITION TO MAINTAIN ACCESS TO THE OTHER SIDE.
13. FURNISHING SYSTEM FEEDS TO SUPPLIED BY SYSTEM MANUFACTURER/ MANUFACTURERS AND ELECTRICAL CONNECTIONS TO BE TURNED IN BY ELECTRICAL CONTRACTOR.
14. CONTRACTOR TO SUPPLY, INSTALL, CONVEY AND VERIFY SECURITY ACCESS CONTROL EQUIPMENT INCLUDING THE SUPPLY, INSTALLATION AND TESTING OF DEVICES, WIRING AND CABLEING AS PER SECURITY CONSULTANT'S SPECIFICATIONS AND DETAILS.
15. TYPICAL WALL OUTLETS TO BE MOUNTED AT 12" A.F.S.
16. REFER TO MECHANICAL & ELECTRICAL DESIGN DRAWINGS FOR SPECIFICATIONS.
17. ALL POWER SOURCES ON THIS PLAN TO BE COORDINATED AND APPROVED BY CLIENT REPRESENTATION AND PARTICIPATION OF ANY MILLWORK WITH APPROVED PROJECT TEAM.
18. CONTRACTOR SHALL CONFIRM ALL QUANTITIES PRIOR TO ORDERING.
19. CONTRACTOR IS RESPONSIBLE FOR:
 - PROVIDING LAYOUTS, DIMENSIONS, DATA FILES, PHONE LINES, ELECTRICAL FIXTURES, ETC.,
 - PROVIDING DIMENSIONS OF EXISTING ELECTRICAL AS REQUIRED.
 - REMOVING ALL EXISTING TAG WIRE SYSTEMS UNDER EXISTING FLOORCOVERING IF REQUIRED.
20. CLIENT IS RESPONSIBLE FOR ALL PWS AND BEST PRICES.
21. THE ELECTRICAL CONTRACTOR MUST NOT TEST AND DO TAKE OFF ON QUANTITY AND MATERIALS REQUIRED BEFORE STARTING SITE AND DESIGNER NOTED THAT EQUIPMENT AND WIRING ARE IN COMPLIANCE WITH ALL APPLICABLE STANDARDS AND THERE ARE NO DISCREPANCIES.

Issue:	
05 ISSUED FOR COORDINATION	16.01.11
06 ISSUED FOR CLIENT REVIEW	16.01.15
07 ISSUED FOR TENDER	16.03.18
09 ISSUED FOR ADDENDUM	17.01.27
10 ISSUED FOR CONSTRUCTION	17.06.19

[illegible]

Our Project Number: 14008	
Designed By: DM,KR,VW,SG	Detailed By: DM,KR,VW,SG,BP
Drawing Number:	

ID4.13