



POWER AND COMMUNICATION NOTATIONS

1. POWER AND COMMUNICATION DRAWINGS TO BE USED FOR LOCATION PURPOSES ONLY:
 - a) REFER TO ELECTRICAL ENGINEERING DRAWINGS FOR DETAILS, SPECIFICATIONS AND REQUIREMENTS.
2. ELECTRICAL AND COMMUNICATION WORK TO COMPLY WITH THE REQUIREMENTS OF THE BUILDING LANDLORD AND AUTHORITIES HAVING JURISDICTION.
3. CONTRACTOR TO REFLECT DISCREPANCIES BETWEEN ENGINEERING AND DESIGN DRAWINGS BY ADDITIONAL ELECTRICAL AND COMMUNICATIONS TO THE COMMITMENT OF WORK.
4. SUBMIT REVISIONS TO THE DESIGNER FOR APPROVAL PRIOR TO COMMENCEMENT OF WORK.
5. DIMENSIONS OF SERVICES ARE TAKEN AT THE CENTRE OF THE SERVICE OR CORD UNLESS OTHERWISE STATED.
6. DIMENSIONS FROM A PARTITION ARE MEASURED FROM FACE OF PARTITION TO CENTRE OF THE SERVICE OR GROUP OF SERVICES, UNLESS OTHERWISE NOTED.
7. DIMENSIONS FROM THE FURNITURE OF THE BUILDING ARE SHOWN FROM FACE OF THE PARTITION OR BACKING TO CENTRE OF THE SERVICE OR CORD UNLESS OTHERWISE NOTED.
8. REFER TO ENGINEERING DRAWINGS FOR SPECIFICATION OF COVER PLATE, RESISTANCE SURFACE, FINISH, COLOUR, ETC. TO BE APPLIED TO THE MOUNTING HEAVY.
9. WHERE POINTS FOR COMMUNICATION SERVICES ARE ADJACENT ON PLAN, SPACED CIRCLED POINTS SHALL BE USED.
10. CONTRACTOR TO MAKE SURE THAT TRACES HAVE COMPLETED THEIR ROUTE OF THE WORK BEFORE BOARDING UP BOTH SIDES OF THE STUDO; THIS IS TO INCLUDE INSPECTIONS AS REQUIRED BY PWD AND APPROVAL BY PLANNING AND BUILDING CODES.
11. CONTRACTOR'S ATTENTION IS DRAWN TO CONTINUE PHONE AND TELEPHONE OUTLETS WITHOUT INTERRUPTION.
12. STAGGER OUTLETS DISTRIBUTED ON OPPOSITE SIDES OF THE SAME PARTITION TO MAINTAIN ACCESS.
13. FURNISHING SYSTEM FEEDS TO BE SUPPLIED BY SYSTEM FURNITURE MANUFACTURER AND ELECTRICAL CONNECTION TO BE MADE BY PHYSICIAN BY ELECTRICAL CONTRACTOR.
14. CONTRACTOR TO SUPPLY, INSTALL, CONNECT AND VERIFY SECURITY ACCESS CONTROL EQUIPMENT TO THE EXISTING SYSTEM AND PROVIDE ALL NECESSARY WIRING AND CABLES AS PER SECURITY CONSULTANT'S SPECIFICATIONS AND DETAILS.
15. TYPICAL WALL MOUNTS TO BE MOUNTED AT 12" AFF.
16. REFER TO MECHANICAL & ELECTRICAL ENGINEERS' DRAWINGS FOR SPECIFICATIONS.
17. ALL POWER SHOWN IN THIS PLAN TO BE CO-ORDINATED AND APPROVED BY CLIENT AS REPRESENTATION AND FABRICATION OF ANY MILLWORK WITH POWER REQUIREMENTS.
18. CONTRACTOR SHALL CONFIRM ALL QUANTITIES PRIOR TO ORDERING.
19. CONTRACTOR'S RESPONSIBLE FOR:
 - ALL ELECTRICAL AND COMMUNICATIONS DATA, NUMBERS, PHONE LINES, ELECTRICAL FITTINGS, ETC.
 - IDENTIFYING AND LOCATING BY TESTING ELECTRICAL AS REQUIRED -
 - * REMOVING ALL EXISTING TAGS AND BEND SYSTEMS UNDERBENDING FLOORCOVERING IF REQUIRED.
20. CLIENT IS RESPONSIBLE FOR ALL POS AND DEPT WORK.
21. THE ELECTRICAL CONTRACTOR MUST NOT TEST AND DO TAKE OFF ON QUANTITY AND MATERIALS REQUIRED BEFORE STARTING CONSTRUCTION PROJECT. LOCALITY LAUNDS AND ELECTRICAL WORK ARE TO BE COMPLETED ON SITE AND DESIGNED UNDER THERE ARE ANY DISCREPANCIES.

05 ISSUED FOR COORDINATION	16.01.11
06 ISSUED FOR CLIENT REVIEW	16.01.15
07 ISSUED FOR TENDER	16.03.18
09 ISSUED FOR ADDENDUM	17.01.27
10 ISSUED FOR CONSTRUCTION	17.06.19

- [illegible]

ID4.17